

NOTICE OF DETERMINATION

TO: Governor's Office of Planning and Research
State Clearinghouse Office
1400 Tenth Street, Room 113
Sacramento, CA 95814

FROM: State Water Resources Control Board
Division of Drinking Water
2 MacArthur Place, Suite 150
Santa Ana, CA 92707

SCH NO.: 2004121068

LEAD AGENCY: Fallbrook Public Utility District (FPUD)

PHONE NUMBER: (760) 728-1125

WATER SYSTEM NO.: 3710702

CONTACT PERSON: Jack Bebee

PROJECT TITLE: Marine Corps Base Camp Pendleton Southern Water System (MCB CamPen SWS), New Well 2604 (Project)

PROJECT LOCATION: Marine Corps Base Camp Pendleton within San Diego County

PROJECT DESCRIPTION: New Well 2604 is part of the Santa Margarita River (SMR) Conjunctive Use Project (CUP). The SMR CUP includes upgrades to existing facilities and construction of new facilities to help meet the long-term water demands of the MCB CamPen SWS and FPUD. Well 2604 is one of three wells being installed in the Upper Ysidora Sub-basin. Construction of the well requires temporary ground disturbance of approximately 57,600-ft², and permanent impacts of approximately 14,400-ft². The well will have a maximum water extraction capacity of up to 2.5 cubic feet per second. The well will be turned off and on according to demand and groundwater levels. An access road, 120-foot wide, with a 20-foot buffer on each side will be installed for power poles, overhead lines, and 12-inch diameter collection pipelines. Using available data and modeling, the well location will be sited to avoid pumping of existing groundwater contamination plumes.

PUBLIC AGENCY APPROVING PROJECT AND CARRYING OUT PROJECT: The Lead Agency is carrying out the Project. The State Water Resources Control Board (State Water Board), Division of Drinking Water (DDW) is a Responsible Agency for the Project. The DDW has issued a drinking water supply permit 05-08-20PA-006 for the above described Project on April 29, 2020 and has made the following California Environmental Quality Act (CEQA) determinations regarding the Project:

1. An Environmental Impact Report was prepared by the Lead Agency for the Project pursuant to the provisions of CEQA.
2. Mitigation measures were made a condition of Lead Agency's approval of the Project.
3. A mitigation monitoring and reporting plan was adopted by the Lead Agency for this Project.
4. A Statement of Overriding Considerations was not adopted by the Lead Agency for the Project.
5. The Project will not have any significant water quality impacts.

A record of water supply permit approval for the Project is available to the general public at the State Water Board, Division of Drinking Water District Office listed below. The Environmental Impact Report is available from the Lead Agency.

Responsible Agency: State Water Board, DDW

District Office: Santa Ana

Signature: 

Name: Ashley Dummer **Title:** District Engineer

Governor's Office of Planning & Research

Date: 4/29/2020

Phone: 714-558-4706

APR 30 2020