

NOTICE OF DETERMINATION

TO: Governor's Office of Planning and Research FROM: State Water Resources Control Board
State Clearinghouse Riverside District
Office P.O. Box 3044 1350 Front Street, Room 2050
Sacramento, CA 95812-3044 San Diego, CA 92101

SUBJECT: Filing of Notice of Determination in compliance with Section 21108 of the Public Resources Code.

SCH#: 2010101061 as amended
WATER SYSTEM #: 3310075

PROJECT TITLE: Chino Desalter Expansion Project

LEAD AGENCY: Chino Basin Municipal Water District
CONTACT PERSON: Curtis Paxton
PHONE NUMBER: 909.218.3729

RESPONSIBLE AGENCY: State Water Resources Control Board (State Water Board)
CONTACT PERSON: J. Steven Williams
PHONE NUMBER: (619) 525-4159


PROJECT LOCATION: Hamner Avenue at Detroit Street, Norco California

PROJECT DESCRIPTION: An interconnection with the Chino II Desalter (CDA) that has recently been constructed. This interconnection will allow the transfer of 3,435 acre-feet per year (AFY) of treated groundwater from the Chino Basin to the 30-inch Arlington Desalter Pipeline that will be used to serve Western's customers, the Cities of Norco and Corona. While the capacity of the pipeline is 20 cubic feet per second (cfs), it is anticipated that the delivery of CDA water to the Arlington system will be at a constant rate of 6 cfs. The groundwater is treated using reverse osmosis and chlorinated prior to delivery to the distribution system. The Chino II Desalter and the Arlington Desalter both use free chlorine as the primary disinfection method.

PUBLIC AGENCY APPROVING PROJECT AND CARRYING OUT PROJECT: This is to advise that the State Water Board has issued a water supply permit amendment 05-20-19PA-016 for the above described Project on November 13, 2019, and has made the following determinations regarding the Project:

1. The Project will not have a significant effect on water quality.
2. An MND and amendments were prepared for this Project pursuant to the provisions of the California Environmental Quality Act (CEQA).
3. Mitigation measures were not made a condition of the issuance of this permit.
4. A mitigation reporting or monitoring plan was not adopted for this Project.
5. Findings were not made pursuant to the provisions of CEQA.
6. A Statement of Overriding Considerations was adopted for this Project.

This is to certify that the record of permit issuance for the Project is available to the general public at the State Water Board, Division of Drinking Water District office noted above. The EIR/EIS and amendments are available from the lead agency.

Signature:  Date: November 13, 2019
Name: J. Steven Williams, P.E. Title: District Engineer

Governor's Office of Planning & Research

NOV 15 2019

STATE CLEARINGHOUSE