Print Form

Summary Form for Electronic Document Submittal

Form F

Lead agencies may include 15 hardcopies of this document when submitting electronic copies of Environmental Impact Reports, Negative Declarations, Mitigated Negative Declarations, or Notices of Preparation to the State Clearinghouse (SCH). The SCH also accepts other summaries, such as EIR Executive Summaries prepared pursuant to CEQA Guidelines Section 15123. Please include one copy of the Notice of Completion Form (NOC) with your submission and attach the summary to each electronic copy of the document.

SCH #: 2017082064

Project Title: City of Etna Public Water System Improvement Project

Lead Agency: City of Etna

Contact Name: Dan Burbank

Email: D.Burbank@etnaca.com Phone Number: (530) 467-5256

Project Location: Etna (*City*) Shasta (*County*)

Project Decription (Proposed actions, location, and/or consequences).

The proposed project includes improvements to the City of Etna's water supply and distribution infrastructure that are needed to replace aging infrastructure, increase system pressures, provide improved fire flows and fire protection in areas of the City, and to ensure a safe and reliable potable water supply for customers in the City's water service area. The original project addressed improvements to the City of Etna's Water Treatment Plant (WTP), including installing ±350 feet of 8- and 12-inch pipeline, and constructing a new ±200,000-gallon water tank, ±382 square-foot filtration building, and a ±1,500 square-foot backwash pond. To date, the water tank has been constructed using Community Development Block Grant funding. The City is now proposing to complete the remaining WTP improvements with revisions and to complete additional improvements to the City's water distribution system; these revisions and additional improvements are addressed in the Addendum. Revisions to the WTP improvements include increasing the size of the new filtration building and converting Reservoir 1 to backwash storage instead of constructing a new backwash pond. Other improvements at the WTP include remodeling the existing WTP building, installing a new 138,000-gallon water tank, installing a new sewer main for backwash discharge, installing a new backup generator, updating the SCADA system, and installing a solar photovoltaic system. Additional improvements to the water system include replacing ±408 water meters throughout the City; upsizing and replacing ±1,076 linear feet of waterlines; and installing ±1,364 linear feet of new water mains to close loops in the system.

Identify the project's significant or potentially significant effects and briefly describe any proposed mitigation measures that would reduce or avoid that effect.

As documented in the Initial Study and proposed Mitigated Negative Declaration and Addendum, project implementation could result in disturbance of nesting migratory birds (if present) and impacts on cultural resources and tribal cultural resources (if present).

Design features incorporated into the project would avoid or reduce certain potential environmental impacts, as would compliance with existing regulations and permit conditions. Remaining impacts can be reduced to levels that are less than significant through implementation of the mitigation measures presented in the Initial Study. Because the City of Etna will adopt mitigation measures as conditions of project approval and will be responsible for ensuring their implementation, it has been determined that the project will not have a significant adverse impact on the environment.

If applicable, describe any of the project's areas of controversy known to the Lead Agency, including issues raised by agencies and the public.

The Lead Agency is not aware of any issues that would be considered controversial, either to the public or to any regulatory agency.

Provide a list of the responsible or trustee agencies for the project.

State Water Resources Control Board, North Coast Regional Water Quality Control Board, California Department of Fish and Wildlife -- Region 1,