Notice of Determination

	_
Appendi	хD

To: 🗵	Office of Planning and Research <i>U.S. Mail:</i> P.O. Box 3044		<i>Street Address:</i> 1400 Tenth Street, Rm 113	From: Public Agency: Address:	Union Sanitary District 5072 Benson Road Union City, CA 94587	
	Sacramento, C/	A 95812-3044	Sacramento, CA 95814	Contact: Phone:	Kevin Chun (510) 477-7608	
×	County Clerk	Alameda		Lead Agency (if diffe	rent from above):	
	County of: Address:	<u>1106 Madison Street, First Floor</u> Oakland, CA 94607	Address:	-		
	-	·		Contact: Phone:	-	

SUBJECT: Filing of Notice of Determination in compliance with Section 21108 or 21152 of the Public Resources Code.

State Clearinghouse Number (if s	ubmitted to State Clearinghouse):	2019029099
Draiget Titles	Standby Dowar Constation System	- Linema de Ducie et

Project litle:	Standby Power Generation System Upgrade Project
Project Applicant:	Union Sanitary District
Project Location (include county):	Alvarada WW/TP Union City, Alamada County

Project Location (include county): ______<u>Alvarado WWTP, Union City, Alameda County</u>

Project Description: The approved Project evaluated in the original IS/NMD included two minimum rated 3.5megawatt (MW) standby engine generators, with room for two future engine generators, with associated electrical equipment. Since that time, electrical load projections for the Alvarado WWTP have decreased significantly due to a new strategy for planned treatment process upgrades. The modified Project scope, addressed in the Addendum to the IS/MND, has been reduced to include three 2.5 MW generators with room for one future engine generator and a reduced construction footprint.

This is to advise that the	Union Sanitary District	has approved the above
	Lead Agency or <a>D Responsible Agency	

described project on <u>February 24, 2020</u> and has made the following determinations regarding the above (Date)

described project:

- 1. The project [will will not] have a significant effect on the environment.
- An Environmental Impact Report was prepared for this project pursuant to the provisions of CEQA.
 ☑ A Negative Declaration was prepared for this project pursuant to the provisions of CEQA.
- 3. Mitigation measures [were D were not] made a condition of the approval of the project.
- 4. A mitigation reporting or monitoring plan [was a was not] adopted for this project.
- 5. A Statement of Overriding Considerations [was s was not] adopted for this project.
- 6. Findings [I were I were not] made pursuant to the provisions of CEQA.

This is to certify that the final EIR with comments and responses and record of project approval, or the Negative
Declaration, is available to the General Public at:
Union Constant District 5070 Denson Dead Union City, CA 04507

	Union S	Sanitary District, 5072 Benson Road	a, Union Cit	Y, CA 94587
Signatur	e (Public Agency)	en & Chu	Title	Associate Engineer
Date	3/13/2020	Date Received	d for filing at	t OPR

Authority cited: Sections 21083, Public Resources Code.
Reference Section 21000-21174, Public Resources Code.