

2019048189

NOTICE OF EXEMPTION

TO: Governor's Office of Planning and Research FROM: State Water Resources Control Board  
State Clearinghouse Fresno District Office  
P.O. Box 3044 265 W. Bullard Ave, Suite #101  
Sacramento, CA 95812-3044 Fresno, CA 93704  
Contact: Chad Fischer  
Phone number: (559) 447-3300

---

SCH#:

WATER SYSTEM #: 1510001

PROJECT TITLE: Arvin CSD – Emergency 1,2,3-TCP Treatment Project – Well No. 13 Facility (Project)

PROJECT LOCATION: Sycamore Road approx. 2,300 ft east of Tower Line Road, Arvin, Kern County, CA

PROJECT DESCRIPTION: The Arvin CSD proposed Project includes the installation of granular activated carbon treatment vessels for the removal of 1,2,3-TCP from the Well No. 13 groundwater supply prior to sending the water to the Arvin CSD distribution system. This is an emergency project to remove the contaminant from the drinking water supply.

PUBLIC AGENCY APPROVING PROJECT AND CARRYING OUT PROJECT: This is to advise that the State Water Resources Control Board (State Water Board) has issued a drinking water supply permit amendment no. 03-12-19PA-004 for the above described Project on April 5, 2019. A record of permit issuance for the Project is available to the general public at the State Water Board, Division of Drinking Water District Office noted above.

**Categorical Exemption Status:**

- Class 1 Existing Facilities  
(California Code of Regulations, Title 14, Division 6, Chapter 3, Article 19, Section 15301)
- Class 2 Replacement or Reconstruction  
(California Code of Regulations, Title 14, Division 6, Chapter 3, Article 19, Section 15302)
- Class 3 New Construction or Conversion of Small Structures  
(California Code of Regulations, Title 14, Division 6, Chapter 3, Article 19, Section 15303)
- Class 4 Minor Alterations to Land  
(California Code of Regulations, Title 14, Division 6, Chapter 3, Article 19, Section 15304)
- Class 6 Information Collection  
(California Code of Regulations, Title 14, Division 6, Chapter 3, Article 19, Section 15306)

**Statutory Exemption Status:**

- Feasibility and Planning Studies  
(California Code of Regulations, Title 14, Division 6, Chapter 3, Article 19, Section 15262)
- Emergency Project  
(California Code of Regulations, Title 14, Division 6, Chapter 3, Article 19, Section 15269)
- Right of way pipelines of less than one mile  
(California Code of Regulations, Title 14, Division 6, Chapter 3, Article 19, Section 15282 (k))

Reason why Project is exempt: This project falls under Class 30 Section 15330 (9) for the construction of emergency groundwater treatment systems in order to remove 1,2,3-TCP from the existing water well for drinking water in Arvin, CA.


LEAD AGENCY: Arvin Community Services District

CONTACT PERSON: Raul Barraza Jr.

PHONE NUMBER: (661) 854-2127

---

2019048189

Signature: 

Date: 4/5/19

Name: Chad Fischer

Title: District Engineer

Governor's Office of Planning & Research

APR 05 2019

STATE CLEARINGHOUSE