

APPENDIX SCA

MIDDLETOWN SEWER CAPACITY ANALYSIS

21000 SANTA CLARA ROAD SUBDIVISION

SANITARY SEWER IMPACT ANALYSIS

DECEMBER 2019

INTRODUCTION

This study was conducted to determine the current capacity of the sewer system downstream of the proposed development as well as the proposed sewer impact from the 21000 Santa Clara Road Development. The existing downstream system is composed of two (2) pump stations and 6" and 8" gravity trunk lines.

EXISTING AND PROPOSED CONDITIONS

The existing site located at 21000 Santa Clara Road is composed of undeveloped land and has no discharge to the adjacent sewer system. There is a pump station (PS #2) located at the north east corner of the property. On the eastern edge of the property and 8" PVC sewer line (Line 1) runs from south to north, discharging into PS #2. On the north edge of the property is a 6" PVC line (Line 7) which runs from west to east, discharging into PS #2. East of the property there is an additional sewer line (Line 3), which is also 8" PVC and discharges into PS #2. PS #2 discharges in to 6" PVC force main, which runs to the west and into Pump Station #3 (PS #3), which discharges into another force main and runs to the treatment plant.

The proposed development at 21000 Santa Clara Road will have 50 new single-family units. All of these units will discharge into Line 1, the 8" sewer line which runs on the east side of the property. These 50 units will connect through two (2) new manholes along the 8" line, each of which will have half of the developments proposed discharge.

See attached maps for the "Existing Sewer Network" and the "Proposed Subdivision Utilities".

Design Analysis

Existing flows entering PS#2 and PS #3 for Dry weather flow are distributed per the following tables (Existing Dry Weather Distribution Tables). This table shows the lines discharging into the pump station, what estimated dry weather flows each pipe carries, and what percent of the flow to each pump station the pipe contributes: (See tables on next page)

Following the table are a series of calculations using Manning's Equation to determine the pipe capacity and the Hazen-Williams equations, in conjunction with system design information, to determine the pump flow rates. Previously collected record data for the pump station run times was also used to determine the existing system demands.

Existing Dry Weather Distribution Tables

		# ESD ₁	gal/day ₂	ft ³ /day	% of PS#2	% of PS#3
Lines to PS#2	Line #1	113	23,730	3,172	19.32%	16.92%
	Line #3	468	98,280	13,138	80.00%	70.06%
	Line #7	4	840	112	0.68%	0.60%
Line to PS#3	Line #8	83	17,430	2,330		12.43%

Total PS #2	585	122,850	16,423
Total PS #3	668	140,280	18,753

Notes:

1 - From 2006 LACOSAN records, drawings, and aerial photography

2 - 210 gpd per ESD from LACOSAN standards




Proposed Additional Dry Weather Flow from Development

	# ESD ₁	gal/day ₂	ft ³ /day	% of PS#2	% of PS#3
New Flow to Line #1	50	10,500	1,404	8.55%	7.49%

Proposed Dry Weather Flow post Development

		# ESD ₁	gal/day ₂	ft ³ /day	% of PS#2	% of PS#3
Lines to PS#2	Line #1	163	34,230	4,576	25.67%	22.70%
	Line #3	468	98,280	13,138	73.70%	65.18%
	Line #7	4	840	112	0.63%	0.56%
Line to PS#3	Line #8	83	17,430	2,330		11.56%

Total PS #2	635	133,350	17,826
Total PS #3	718	150,780	20,156



- SS — SS — (E) SS MAIN
- FM — FM — (E) SS FORCE MAIN
- PS — PS — (P) SS SYSTEM



Santa Clara Development

Legend



Google Earth

© 2018 Google

4000 ft



EXISTING DEMANDS ON SYSTEM

Dry-Weather 6/6/06 – 6/11/06

Pump Station #2

Pump 1 - 8.2hrs / 5 days = 1.64hrs/day

Pump 2 - 8.4hrs / 5 days = 1.68hrs/day

Existing Usage – 3.32hrs / 24hrs = **13.83%**

Pump Station #3

Pump 1 – 9.8hrs / 5 days = 1.96hrs/day

Pump 2 – 8.9hrs / 5 days = 1.78hrs/day

Existing Usage - 3.74hrs / 24hrs = **15.58%**

Wet-Weather 10yr Event (12/30/06 – 1/3/06)

Pump Station #2

Pump 1 - 29hrs / 4 days = 7.25hrs/day

Pump 2 - 33hrs / 4 days = 8.25hrs/day

Existing Usage @ 10yr event - 15.5hrs / 24hrs = **64.58%**

Pump Station #3

Pump 1 – 26.9hrs / 4 days = 6.73hrs/day

Pump 2 – 27.9hrs / 4 days = 6.98hrs/day

Existing Usage @ 10yr event – 13.71hrs / 24hrs = **57.13%**

PUMP PERFORMANCE

Hazen-Williams Friction Loss Equation (Solved for Friction Loss)

Variables

Q = Quantity (cfs)

V = Velocity (ft/s)

D = Pipe Diameter (ft)

A = Pipe Area (ft²)

L = Pipe Length (ft)

C = Hazen-Williams Coefficient (from table below)

Z1 - Z2 = Elevation Difference (ft)

g = Acceleration due to gravity (32.174 ft/s²)

k = Unit conversion factor (1.318 for English units)

K_m = Minor Loss Coefficient (from table below)

h_f = Major (friction) Loss (ft)

h_m = Minor Loss (ft)

Equations

$$h_f = L \left[\frac{V}{k C} \left(\frac{4}{D} \right)^{0.63} \right]^{1 / 0.54} \quad h_m = K_m \frac{V^2}{2g} \quad Q = VA \quad A = \frac{\pi}{4} D^2$$

Pump Station #2

Q = 1.1898 ft³/s

V = 6.0594 ft/s

D = 0.5 ft

A = 0.1963 ft²

L = 1726 ft

C = 145 (PVC)

Z1 - Z2 = 6.55 ft

K_m = 7.05

h_f = 32.73 ft

h_m = 4.02 ft

Pump Station #3

Q = 1.4009 ft³/s

V = 4.0128 ft/s

D = 0.6667 ft

A = 0.3491 ft²

L = 10783 ft

C = 145 (PVC)

Z1 - Z2 = 57 ft

K_m = 8.1

h_f = 68.15 ft

h_m = 2.03 ft


Table of Hazen-Williams Coefficients

Material	C	Material	C
Asbestos Cement	140	Copper	130-140
Brass	130-140	Galvanized iron	120
Brick sewer	100	Glass	140
<i>Cast-Iron:</i>		Lead	130-140
New, unlined	130	Plastic	140-150
10 yr. old	107-113	<i>Steel:</i>	
20 yr. old	89-100	Coal-tar enamel lined	145-150
30 yr. old	75-90	New unlined	140-150
40 yr. old	64-83	Riveted	110
<i>Concrete/Concrete-lined:</i>			
Steel forms	140	Tin	130
Wooden forms	120	Vitrif. clay (good condition)	110-140
Centrifugally spun	135	Wood stave (avg. condition)	120

Table of Minor Loss Coefficients (Km is unit-less)

Fitting	Km	Fitting	Km
<i>Valves:</i>		<i>Elbows:</i>	
Globe, fully open	10	Regular 90°, flanged	0.3
Angle, fully open	2	Regular 90°, threaded	1.5
Gate, fully open	0.15	Long radius 90°, flanged	0.2
Gate 1/4 closed	0.26	Long radius 90°, threaded	0.7
Gate, 1/2 closed	2.1	Long radius 45°, threaded	0.2
Gate, 3/4 closed	17	Regular 45°, threaded	0.4
Swing check, forward flow	2		
Swing check, backward flow	infinity	<i>Tees:</i>	
		Line flow, flanged	0.2
<i>180° return bends:</i>		Line flow, threaded	0.9
Flanged	0.2	Branch flow, flanged	1.0
Threaded	1.5	Branch flow, threaded	2.0
<i>Pipe Entrance (Reservoir to Pipe):</i>		<i>Pipe Exit (Pipe to Reservoir)</i>	
Square Connection	0.5	Square Connection	1.0
Rounded Connection	0.2	Rounded Connection	1.0
Re-entrant (pipe juts into tank)	1.0	Re-entrant (pipe juts into tank)	1.0

#2



FLYET

CAPACITY OF GRAVITY LINES CONTRIBUTING TO PUMP STATION #2

Manning's Equation (Solved for Velocity)

Variables

Q = Quantity (cfs)

V = Velocity (ft/s)

A = Area ft²

K = Conversion Factor for English Units

n = Manning's Coefficient (From Table)

P = Wetted Perimeter (ft)

S = Slope (EGL ft/ft)

Equations

$$Q = VA \quad V = \frac{k}{n} \left(\frac{A}{P} \right)^{2/3} S^{1/2}$$

Line 1

Q = 0.8227cfs
V = 2.3567 ft/s
A = 0.3491 ft²
K = 1.49
n = 0.011
P = 2.0945 ft
S = 0.0033 ft/ft

Line 3

Q = 0.8227cfs
V = 2.3567 ft/s
A = 0.3491 ft²
K = 1.49
n = 0.011
P = 2.0945 ft
S = 0.0033 ft/ft

Line 7

Q = 0.3819cfs
V = 1.9453 ft/s
A = 0.1963 ft²
K = 1.49
n = 0.011
P = 1.5708 ft
S = 0.0033 ft/ft

Table of Manning's Coefficients

Material	Manning n	Material	Manning n
<i>Natural Streams</i>		<i>Excavated Earth Channels</i>	
Clean and Straight	0.030	Clean	0.022
Major Rivers	0.035	Gravelly	0.025
Sluggish with Deep Pools	0.040	Weedy	0.030
		Stony, Cobbles	0.035
<i>Metals</i>		<i>Floodplains</i>	
Brass	0.011	Pasture, Farmland	0.035
Cast Iron	0.013	Light Brush	0.050
Smooth Steel	0.012	Heavy Brush	0.075
Corrugated Metal	0.022	Trees	0.15
<i>Non-Metals</i>			
Glass	0.010	Finished Concrete	0.012
Clay Tile	0.014	Unfinished Concrete	0.014
Brickwork	0.015	Gravel	0.029
Asphalt	0.016	Earth	0.025
Masonry	0.025	Planed Wood	0.012
		Un-planed Wood	0.013
Corrugated Polyethylene (PE) with smooth inner walls ^{a,b}			0.009-0.015
Corrugated Polyethylene (PE) with corrugated inner walls ^c			0.018-0.025
Polyvinyl Chloride (PVC) with smooth inner walls ^{d,e}			0.009-0.011

References

Footnotes refer to Manning n table above. .

^a Barfuss, Steven and J. Paul Tullis. Friction factor test on high density polyethylene pipe. Hydraulics Report No. 208. Utah Water Research Laboratory, Utah State University. Logan, Utah. 1988.

^c Barfuss, Steven and J. Paul Tullis. Friction factor test on high density polyethylene pipe. Hydraulics Report No. 208. Utah Water Research Laboratory, Utah State University. Logan, Utah. 1994.

^e Bishop, R.R. and R.W. Jeppson. Hydraulic characteristics of PVC sewer pipe in sanitary sewers. Utah State University. Logan, Utah. September 1975.

^d Neale, L.C. and R.E. Price. Flow characteristics of PVC sewer pipe. Journal of the Sanitary Engineering Division, Div. Proc 90SA3, ASCE. pp. 109-129. 1964.

^b Tullis, J. Paul, R.K. Watkins, and S. L. Barfuss. Innovative new drainage pipe. Proceedings of the International Conference on Pipeline Design and Installation, ASCE. March 25-27, 1990.

Existing Flows to PS#2

Existing flows below are derived using the pump performance rate and number of hours operated during both dry weather and wet weather (10-year storm) conditions.

Existing Dry Weather Flow to Pump Station #2

$$(1.1898 \text{ ft}^3/\text{s})(3.32 \text{ hours}) = 14,222 \text{ ft}^3/\text{day}$$

$$\text{Capacity} - 3.32\text{hr}/24\text{hr} = 13.8\% \text{ capacity}$$

Existing Wet Weather Flow to Pump Station #2

$$(1.1898 \text{ ft}^3/\text{s})(15.5 \text{ hours}) = 66,390 \text{ ft}^3/\text{day}$$

$$\text{Capacity} - 15.5\text{hr}/24\text{hr} = 64.6\% \text{ capacity}$$

Existing Flows to Line 1

Line 1 – Dry Weather is 19.3% of Total Pumped

$$\text{Daily flow} = 0.193 \times 14,222 \text{ ft}^3/\text{day} \times 1 \text{ day} = 2,747 \text{ ft}^3$$

$$\text{Average Flow} = 2,747 \text{ ft}^3 / 86,400 \text{ sec} = 0.0318 \text{ ft}^3/\text{s}$$

$$\text{Peak Flow} = 2.8 \times 0.0318 \text{ ft}^3/\text{s} = 0.089 \text{ ft}^3/\text{s}$$

$$\text{Total Capacity} = 0.8227 \text{ ft}^3/\text{s}$$

Pipe @ 10.8% capacity

Line 1 – Wet Weather is apx. 46% of total flow pumped (per previous analysis of sewer system)

$$\text{Daily flow} = 0.4671 \times 66,390 \text{ ft}^3/\text{day} \times 1 \text{ day} = 31,010 \text{ ft}^3$$

$$\text{Average Flow} = 31,010 \text{ ft}^3 / 86,400 \text{ sec} = 0.3589 \text{ ft}^3/\text{s}$$

$$\text{Peak Flow} = 1.5 \times 0.3589 \text{ ft}^3/\text{s} = 0.5384 \text{ ft}^3/\text{s}$$

$$\text{Total Capacity} = 0.8227 \text{ ft}^3/\text{s}$$

Pipe @ 65.4% capacity

Conclusion

The existing sewer system including gravity mains, pump station, and force mains have the capacity to support the proposed project. See below for a summary of the proposed impacts to the existing system on a flow rate and percentage of capacity basis.

Line #1

New Flow is 50 residential units @ 210 gpd each = 1,404 ft³/day

Average Flow = 0.0163 ft³/sec

Peak Flow = 2.8 x 0.0163 = 0.0455 ft³/sec

Additional 5.5% of capacity due to development

After development the pipe will be at:

18.0% of capacity during dry weather

70.9% of capacity during 10-year storm event

Line #3, #7, and #8 will not be affected by this project.

Pump Station #2

New Flow is 50 residential units @ 210 gpd each = 1,404 ft³/day

1,404 ft³ / 1.1898 ft³/s = 1,180 sec

1,180 sec / 86,400 sec = 1.36%

New flow is 1.36% of pump station capacity

Pump Station will be:

@ 15.16% of capacity during dry weather flows

@ 66.0% of capacity during 10-year storm events

Pump Station #3

New Flow is 50 residential units @ 210 gpd each = 1,404 ft³/day

1,404 ft³ / 1.401 ft³/s = 1,002 sec

1,002 sec / 86,400 sec = 1.16%

New flow is 1.16% of pump station capacity

Pump Station will be:

@ 16.74% of capacity during dry weather flows

@ 58.29% of capacity during 10-year storm events