

State Water Resources Control Board

NOTICE OF INTENT TO ADOPT A MITIGATED NEGATIVE DECLARATION

(Pursuant to CEQA Section 21092 and CEQA Guidelines Section 15072)

PROJECT TITLE: Del Oro Water Company-Traver District, Traver Well No. 3 1,2,3-Trichloropropane Treatment (Project)

WATER SYSTEM#: 5400553

APPLICANT: State Water Resources Control Board (State Water Board)

PROJECT LOCATION: North of Jacobs Drive between Church Drive and Baker Drive in Traver; Tulare County

PROJECT DESCRIPTION: Del Oro Water Company- Traver Water District proposes a water treatment system for the remediation of 1,2,3-TCP. This system will include installing: two approximately 12-foot diameter and 15-foot tall granular activated carbon (GAC) vessels, an estimated 22-foot diameter 19-foot tall large supply tank for backwash water, an approximately 1,500 gallon per minute backwash pump station, an estimated seven to nine and half foot high, 100-foot squared chlorination building, an approximately 1,125-foot squared concrete truck pad, and a generator for emergency power. An estimated 674-feet of four to 18-inch diameter piping will also be installed to connect the various components of the system. General site improvements will also include a paved driveway, double access gate, and perimeter fencing.

COMMENT PERIOD:

STARTING DATE: October 11, 2019

ENDING DATE: November 9, 2019

NOTICE IS HEREBY GIVEN that the State Water Board intends to adopt a Mitigated Negative Declaration for the Project in accordance with California Environmental Quality Act Guidelines.

ADDRESS WHERE COPIES OF THE PROPOSED MITIGATED NEGATIVE DECLARATION, INITIAL STUDY AND REFERENCE ARE AVAILABLE FOR REVIEW:

State Water Resources Control Board
Visalia District Office
265 West Bullard Avenue, Suite 101
Fresno, CA 93704

The Project site is not present on any of the lists enumerated under section 65962.5 of the government code.

E. JOAQUIN ESQUIVEL, CHAIR | EILEEN SOBECK, EXECUTIVE DIRECTOR

If applicable, describe any of the project's areas of controversy known to the Lead Agency, including issues raised by agencies and the public.

Areas of known controversy:

- No known areas of controversy.

Issues raised by agencies and the public

- No issues raised by agencies and the public.

Provide a list of the responsible or trustee agencies for the project.

Responsible and Trustee Agencies:

- San Joaquin Valley Air Pollution Control District
- California Department of Fish and Wildlife
- Central Valley Regional Water Quality Control Board (Fresno)
- Tulare County