

NOTICE OF INTENT TO ADOPT MITIGATED NEGATIVE DECLARATION

The City of Angels is the Lead Agency for and intends to consider adoption of a mitigated negative declaration pursuant to Section 21092 and 21092.3 of the Public Resources Code and Section 15072 the California Environmental Quality Act (CEQA) for the following project:

Project Title: Phase 1 Sewer Line Replacement Project

Project Location: The proposed project is located in the City of Angels Camp, Calaveras County, in the central Sierra Nevada foothills. The proposed project is in a portion of Section 28, 33 and 34, T3N, R13E and Section 03, T2N, R13E Mount Diablo Baseline and Meridian, Calaveras County, CA. Angels Camp USGS 7.5-minute Quadrangle. The proposed project would pass through 32 Assessor's Parcel Numbers including: 062-017-016, 062-017-015, 062-003-062, 062-004-043, 062-013-018, 062-013-019, 062-013-043, 062-013-044, 062-013-022, 062-013-023, 062-013-024, 062-013-025, 062-011-042, 062-014-018, 062-014-046, 062-003-019, 062-003-063, 062-003-067, 062-003-066, 062-003-042, 062-006-ROW, 062-004-ROW, 062-004-044, 062-009-057, 062-009-ROW, 062-009-016, 062-009-035, 062-013-039, 062-013-041, 062-013-042, 062-014-002, and 064-004-001.

Project Description: The proposed project includes upsizing and/or replacing approximately 5,446 linear feet of deteriorating sewer line as two separate segments: (1) the East Trunk segment which encompasses the southern portion of the proposed project; and (2) the Vallecito Road segment which encompasses the northern portion of the proposed project. Construction methods to upsize and/or replace the existing sewer line include the following: Remove and replace; Pipe bursting; Cured-in-place pipe liner; or New pipe installation

Pipe sizes along the existing sewer line vary between 10 and 15 inches, and the proposed project would upsize the sewer line at various locations to a maximum 18-inch pipe to increase flow capacity. The proposed project would replace most of the existing clay pipes with polyvinyl chloride standard dimension ratio 35 pipes.

Mitigated Negative Declaration: A copy of the Mitigated Negative Declaration, Initial Study, and supporting documents are available for review by contacting the Angels Camp Community Development Department as at the address shown below during regular business hours M-Th 8-12 and 1-4 p.m. Comments on the Initial Study and proposed Mitigated Negative Declaration should be sent to the address below or by email to tuolandplanner@gmail.com.

City of Angels Camp
Attn: Amy Augustine City Planner
P.O. Box 667
200 Monte Verde Street, Suite #B (Hand delivery)
Angels Camp, CA 95222
Phone: (209) 736-1346 Ext. 5

Comments on the proposed draft Mitigated Negative Declaration should be submitted during the public review period starting **January 30, 2020 and ending February 28, 2020.**

No sites enumerated pursuant to Government Code Section 65962.5 regarding hazardous materials have been identified on site.

/s/Amy Augustine, AICP - City Planner

Publication Date: January 30, 2020