

NOTICE OF EXEMPTION
(Categorical)

2020020076

TO: Governor's Office of Planning and Research
State Clearinghouse
P.O. Box 3044
Sacramento, CA 95812-3044

FROM: State Water Resources Control Board
Central District Office
500 North Central Avenue, Suite 500
Glendale, CA 91203
Contact: Sutida Bergquist
Phone number: (818) 551-2004

SCH#:

WATER SYSTEM #: CA1900007

PROJECT TITLE: Fire Camp 14 Life Safety Improvement Project (Capital Project No. 87159) (Project)

PROJECT LOCATION: 35100 San Francisquito Canyon Road in Saugus, Santa Clarita, Los Angeles County.

PROJECT DESCRIPTION: The Project included construction of two new wells and a surface water treatment plant and replacement of the existing storage tank with a new storage tank. The treatment plant is in a 356 ft.² building, has a capacity of 65 gpm, and features a cartridge filtration system and chlorination system.

PUBLIC AGENCY APPROVING PROJECT AND CARRYING OUT PROJECT: This is to advise that the State Water Board has issued Water Supply Permit #04-16-19P-011 for the above described Project on December 24, 2019. A record of permit issuance for the Project is available to the general public at the State Water Board, Division of Drinking Water Central District office as noted above.


Categorical Exemption Status:

- Class 1 Existing Facilities
(California Code of Regulations, Title 14, Division 6, Chapter 3, Article 19, Section 15301(a))
- Class 2 Replacement or Reconstruction
(California Code of Regulations, Title 14, Division 6, Chapter 3, Article 19, Section 15302(c))
- Class 3 New Construction or Conversion of Small Structures
(California Code of Regulations, Title 14, Division 6, Chapter 3, Article 19, Section 15303)
- Class 4 Minor Alterations to Land
(California Code of Regulations, Title 14, Division 6, Chapter 3, Article 19, Section 15304)

Reason why Project is exempt: The Project involves minor alterations as all new facilities under this project are located on publicly-owned land. The new wells have an individual capacity of 20 gpm and a combined capacity of 30 gpm, less than the existing well's capacity of 48 gpm. The old well and treatment plant are still in place but serve as backup facilities for the new wells and treatment plant. The new storage tank was built directly on the site of the old storage tank. The old and new storage tank diameters are 37 feet and 47 feet, respectively, each with a 250,000 gallon capacity. During construction of the new storage tank, three 7,650-gallon storage tanks were temporarily installed adjacent to the storage tank site to provide potable water storage. The old storage tank and the temporary storage tanks have been removed from the premises.

LEAD AGENCY: County of Los Angeles, Department of Public Works
CONTACT PERSON: Alioune Dioum, P.E.
PHONE NUMBER: (626) 300-3273

Governor's Office of Planning & Research

Signature: 

Date: February 4, 2020

FEB 04 2020

Name: Sutida Bergquist, P.E.

Title: District Engineer

STATE CLEARINGHOUSE