

NOTICE OF EXEMPTION
(Categorical)

2020020352

TO: Governor's Office of Planning and Research State Clearinghouse Office P.O. Box 3044 Sacramento, CA 95812-3044	FROM: State Water Resources Control Board Sacramento – District 9 Office 1001 I Street, 13 th Floor Sacramento, CA 95814
-----------------------------------------------------------------------------------------------------------------------------------	-----------------------------------------------------------------------------------------------------------------------------------------------------

SYSTEM #: 5710013

PROJECT TITLE: Operation of NC-Youth Regional Treatment Center- Sacred Oaks Project (Project)

LEAD AGENCY: State Water Resources Control Board

CONTACT PERSON: Ali Rezvani

PHONE NUMBER: 916-449-5681

PROJECT LOCATION: 33100 County Road 31, in the City of Davis, in the County of Yolo

PROJECT DESCRIPTION: The NC-Youth Regional Treatment Center proposes to construct a new public water supply well with a 400-foot depth, a water storage tank, booster pumps, a diesel engine driven fire pump, and a water distribution system to the North California Youth Regional Treatment Center.

PUBLIC AGENCY APPROVING PROJECT AND CARRYING OUT PROJECT: This is to advise that the State Water Resources Control Board (State Water Board) has determined that the Project is exempt from the California Environmental Quality Act and will issue a drinking water supply permit for the operation of the above described Project. A record of permit issuance for the Project is available to the general public at the State Water Board, Division of Drinking Water District office noted above.

Categorical Exemption Status:

- Class 3 New Construction or Conversion of Small Structures
(CCR, Title 14, Chapter 3, Division 6, Article 19, Section 15303)

Reason why Project is exempt: The State Water Board, Division of Financial Assistance, Special Project Review (SPR) Unit staff recommend that this Project is categorically exempt from CEQA pursuant to California Code of Regulations (CCR), Title 14, Section 15303, Class 3, because the storage tank will be less than 100,000-gallon capacity and the well will not exceed 125 gallons per minute.

Signature: _____	Date: <u>February 12, 2020</u>
Name: <u>Ali Rezvani</u>	Title: <u>District Engineer</u>

Governor's Office of Planning & Research
 FEB 18 2020
 STATE CLEARINGHOUSE