

Miller Drilling Co.  
329 N. Main St.  
Templeton, CA 93465  
(805) 434-1888

# Miller Drilling Co.

Contractors License No. 324634

## PUMP TEST REPORT

WELL OWNER: RYAN LOVEJOY Job# 20922  
BILLING ADDRESS: 23701 UNIT A EAST CLIFF DR Pump Set: \_\_\_\_\_ Well #: 5"X1 1/4"  
SANTA CRUZ, CA 95062 Pump Size: 1 HP Well Depth: 240  
rlovejoy1987@yaheo.com Testing Method: EXISTING PUMP  
Perf Rec: \_\_\_\_\_ NA \_\_\_\_\_

Standing Level Before Test: 55.69 LOCATION: 11111 BITTER WATTER RD

### TESTING

TIME	PUMPING LEVEL	WATER CONDITION	WATER/BOWLS	GPM
8:50	START	CLEAR NO ODOR		15.25
8:55	74.32	CLEAR NO ODOR		15
9:10	81.26	CLEAR NO ODOR		15
9:20	84.11	CLEAR NO ODOR		15
10:05	91.56	CLEAR NO ODOR		14.8
11:00	96.36	CLEAR NO ODOR		14.8
11:35	98.11	CLEAR NO ODOR		14.6
12:00	101.12	CLEAR NO ODOR		14.6
12:30	101.36	CLEAR NO ODOR		14.6
12:50	102.24	CLEAR NO ODOR		14.6

Notes: METER START 137523 METER STOP 141067 = 14.77 GPM AVERAGE  
STANDING LEVEL AFTER TEST: 10 MIN 80.88 - 15 MIN 78.79 - 20 MIN 77.81  
STANDING LEVEL AFTER TEST: AFTER 5 MINUTES 84.12  
FINAL TEST RESULTS: Produced: 14.6 GPM for 4 hours on: 2/22/2018  
Test Run By: CHRIS A

Abalone Coast Analytical, Inc.  
 141 Suburban Rd, Ste C-1 San Luis Obispo CA, 93401  
 Phone: 595-1080 Fax: 595-1075  
 ELAP #2681

Order #: 18-1273  
 Date/Time Rec'd: 2/22/18 1401

Miller Drilling Company  
 301 North Main Street  
 Templeton, CA 93486

Contact: Kurt Bollinger  
 Phone: 434-1888  
 Sampler: Chris Andres

Sample #	Sample Description	Date / Time	Analysis	Method	Result	Units	RL	Completed
-2	#20922, Lovejoy	2/22/18	Total Coliform	SM 9223 B.	Absent	/100ml	1	02/23/18
	11111 Bitterwater Rd		E-coli	IDEXX	Absent	/100ml	1	02/23/18

This sample passes water quality standards for Total Coliform and E. Coli Bacteria.

Report Completion Date: 2/23/18

Reviewed By: *Erika Frost*  
 Erika Frost, Lab Director

**Definitions:**

Absent = Less than 1 CFU/100mLs

Present = 1 or more CFU/100mLs

CFU = Colony Forming Unit

RL = Reporting Limit

State of California CDPH ELAP 2681