

**NOTICE OF INTENT TO ADOPT A
MITIGATED NEGATIVE DECLARATION**

PROJECT TITLE: St. Anthony On-site Sewer and Water Distribution System (Project)
APPLICANT: Pueblo Unido Community Development Corporation
LEAD AGENCY: State Water Resources Control Board
PROJECT SRF#: C-06-8006-110 & 3301380-001C

PROJECT LOCATION:

Project is located immediately east of Lincoln Street and approximately 0.25 miles north of Avenue 68 in the unincorporated community of Mecca, Riverside County, California. The Project is not located on a site on any of the lists enumerated under Section 65962.5 of the Government Code.

PROJECT DESCRIPTION:

The Project includes the construction of an on-site sewage collection system and laterals that will convey sewage from each mobile home to the existing Coachella Valley Water District (CVWD) lift station at Lincoln Street and Avenue 68. The on-site sewer system will consist of approximately 32 manholes, approximately 2,200 linear feet of 4" laterals, and approximately 7,250 linear feet of 8" sewer main pipe.

The proposed on-site water distribution system will consist of approximately 8,350 linear feet of 6" water main interconnecting the mobile homes to CVWD's future off-site water main located under Lincoln Street. In addition, a 20,000-gallon hydropneumatics water storage tank will be located on the northeast corner of the Project area to serve as an emergency water supply and meet fire flow for the Mobile Home Property.

The Project will grade the entire site in ensure proper drainage, including mobile home unit pads and streets with curb and gutters to carry stormwater flow to on-site retention facilities to be located at the southernmost portion of the site with a combined storage capacity of approximately 284,484 cubic yards. The Project will also install subsurface tile drainage in accordance with the CVWD standards below the retention facilities with a gravel filtration system that allows stormwater to percolate into the groundwater basin.

REVIEW PERIOD START DATE: May 15, 2020

REVIEW PERIOD END DATE: June 15, 2020

AVAILABILITY OF THE DOCUMENT: Copies of the Mitigated Negative Declaration are available for review at the following location:

State Water Resources Control Board
Division of Financial Assistance
Environmental Review Unit
1001 I Street, 16th Floor
Sacramento, CA, 95814

COMMENTS ON THE DOCUMENT: Comments on the Mitigated Negative Declaration should be submitted to the State Water Resources Control Board by mail at the address listed above, or by email to Kristen.Way@waterboards.ca.gov. Comments must be submitted no later than 5:00 pm on June 15 2020.

ADDITIONAL INFORMATION: For more information on the Project please contact Kristen Way at (916) 341-5879, or at Kristen.Way@waterboards.ca.gov.