ADDENDUM TO INITIAL STUDY/ MITIGATED NEGATIVE DECLARATION (SCH No. 2020059026)

SAN MATEO UNION HIGH SCHOOL DISTRICT MILLS HIGH SCHOOL ATHLETICS COMPLEX PROJECT

April 2021

Prepared For: San Mateo Union High School District 650 N. Delaware Street San Mateo, CA 94401

Prepared by: Grassetti Environmental Consulting 7008 Bristol Drive Berkeley, CA 94705

1.0 INTRODUCTION AND BACKGROUND

1.1 INTRODUCTION

This environmental document is an Addendum to the San Mateo Union High School District's (SMUHSD or District) Mills High School Athletics Complex Project Initial Study/Mitigated Negative Declaration (IS/MND), State Clearinghouse No. 2020059026, adopted in October 2020 by the SMUHSD. The SMUHSD is the lead agency under CEQA.

This Addendum addresses refinements to the project's light impacts analysis. As demonstrated in this Addendum, the IS/MND continues to serve as the appropriate document addressing the environmental impacts of these improvements pursuant to California Environmental Quality Act (CEQA).

1.2 BACKGROUND

The IS/MND was prepared to address construction and operational impacts of the proposed Mills High School Athletics Complex Project (Approved Project). The IS/MND evaluated potential environmental effects on aesthetics, agriculture and forestry resources, air quality, biological resources, cultural resources, geology and soils, greenhouse gas emissions, hazards and hazardous materials, hydrology and water quality, land use and planning, mineral resources, noise, population and housing, public services, recreation, transportation/traffic, utilities and service systems, and mandatory findings of significance. All impacts identified in the IS/MND were either less than significant or have been mitigated to below a level of significance through implementation of mitigation measures identified in the document and subsequently incorporated into the project by IS/MND the District. One of the mitigation measures, Mitigation AES-1, addressed altering the lighting plan to assure that light and glare impacts to adjacent properties would be less than 10,000 candelas. The lighting plan has been adjusted and additional analysis indicates that the light and glare impacts of the project would now be below this threshold and therefore the mitigation measure is no longer necessary to reduce the impact to a less-thansignificant level.

1.3 PURPOSE OF ADDENDUM TO THE IS/MND

When a proposed project is changed, there are changes in environmental setting, or additional analysis is required, a determination must be made by the Lead Agency as to whether an Addendum or Subsequent EIR or MND is prepared. CEQA Guidelines Sections 15162 and 15164 set forth criteria to assess which environmental document is appropriate. The criteria for

determining whether an Addendum or Subsequent MND is prepared are outlined below. If the criteria below are true, then an Addendum is the appropriate document:

- No new significant impacts will result from the project or from new mitigation measures.
- No substantial increase in the severity of environmental impact will occur.
- No new feasible alternatives or mitigation measures that would reduce impacts previously found not to be feasible have, in fact, been found to be feasible.

Based upon the information provided in Section 3.0 of this document, the changes to the Approved Project will not result in new significant impacts or substantially increase the severity of impacts previously identified in the IS/MND, and there are no previously infeasible alternatives that are now feasible. None of the other factors set forth in Section 15162(a)(3) are present. Therefore, an Addendum is appropriate. This Addendum addresses the environmental effects of the revised lighting plan and analysis.

2.0 PROJECT DESCRIPTION

2.1 Project Location And Setting

Mills High School is located at 400 Murchison Drive in the southeastern area of the City of Millbrae adjacent to the City of Burlingame, in San Mateo County. Regionally, the campus is accessed via from US Highway 101, via Millbrae Avenue and the Millbrae BART Station which is located approximately a quarter of a mile northeast of the campus.

The Mills High School campus is located north of Sequoia Avenue, southeast of Millbrae Avenue, southwest of South Magnolia Avenue, and northwest of Murchison Avenue. The project site, which encompasses the baseball field, multi-use field, tennis courts, and swimming pool, is at the northeastern and northwestern edges of the campus.

2.2. Previously Approved Project

The previously approved project is a reconfigured and improved athletics complex for the school including:

- Replacement of the existing practice field with a baseball field including a PA system and lighting;
- Replacing the tennis courts with a new soccer and softball field, with a PA system and lighting;
- Upgrades to the existing multi-use field;
- Construction of seven replacement tennis courts; and

• Adding lighting to the existing swim complex.

The adopted Mitigated Negative Declaration included the following mitigation measure regarding light and glare impacts:

Measure AES-1: Reduce Glare Impacts. To reduce significant glare impacts on the adjacent residents at their rear property lines to levels below 25,000 candelas, which is the threshold of significance the lighting proposed for the outfield shall be redesigned so that glare would not exceed 25,000 candelas at the rear property lines. This would reduce glare to acceptable levels.

2.2 PROPOSED PROJECT REVISIONS

The current project proposes minor adjustments to the lighting plan for the project described in the IS. No other changes to the project would occur. In addition, it has been determined on the basis of expert review that 25,000 candelas may not be adequately protective to assure that the impact would be less than significant. A revised threshold of 10,000 candelas has been selected by the District, on the basis of expert opinion supported by evidence, to assure that the impacts to nearby residents would be less than significant.

The project lighting engineers (Zeiger and Associates) and light system designers (Musco Lighting), conducted additional analyses to determine the actual lighting impacts to residents of the nearby houses and condominiums. The results of this analysis are discussed below.

3.0 ENVIRONMENTAL ANALYSIS

As explained in Section 1.0, this Addendum has been undertaken pursuant to the provisions of CEQA Sections 15162 and 15164 to provide the District with the factual basis for determining whether any changes in the project, any changes in circumstances, or any new information since the IS/MND was certified require additional environmental review or preparation of a Subsequent MND or EIR to the IS/MND previously prepared.

The environmental analysis provided in the IS/MND remains current and applicable to the proposed project in all areas, with a reduced impact on light and glare, as summarized below:

Aesthetics – Regarding lighting, the IS/MND concluded:

The glare impacts on adjacent residents would be limited to the areas shown in Figure 11, below. The figure indicates the maximum calenda, or amount of glare an observer would see when facing the brightest light source from any direction. High glare is considered to be 150,000 or more candelas. Significant glare is defined as 25,000 to 75,000 candelas, which is equivalent to the high beam headlights on a car. Minimal to

no glare is 500 or fewer candelas, or equivalent to a 100-watt incandescent light bulb. Figure 11 shows that the glare from the lighting that some of the residents adjacent to the baseball field would experience would be up to 100,000 candelas. Additional lighting diagrams are provided in Appendix B. Because the residents located adjacent to the baseball field would be exposed to glare exceeding 25,000 candelas, the lighting would result in **significant glare impacts**. However, implementation of Mitigation Measure AES-1, below, would reduce these impacts to a **less than significant** level.

Adjustments were made to the lighting plan and a refined glare light and impact analysis was conducted for the project (Attachment 1 to this Addendum). That analysis concluded that the IS glare impact analysis overstated the off-site glare values of these projects. That analysis was based a 2D model that shows values at the grade of the field(s) (i.e., on the field itself) and does not consider glare above or below this grade, such as at the elevations of the adjacent residential properties. At the site, there are residential properties that are either at a higher elevation than the field (thus looking down at the field), or a lower elevation than the field (thus looking up at the field). In order to address this deficiency, Musco added linear grids that follow along the residential property lines. These grids address the varied elevations along these lines as well, thus offering more accurate light and glare impact numbers. The measurements shown along the residential property lines are taken at $+3^{2}$ relative to the grade elevation, which is the standard for where light readings are taken. Per the latest Musco plans and analysis, the highest candela reading at the property lines adjacent to the Mills fields would be 8,644 candela, far below the 25,000-candela standard used in the IS, and also below the more conservative 10,000-candela threshold used in this Addendum.

In summation, the project would have lower off-site glare than that described in the IS, and would conform with both the IS's 25,000 candela and the new 10,000 candela significance thresholds. Therefore the impact would be less than significant and Mitigation Measure AES-1 is no longer required. That measure has been removed from the IS and the Mitigation Monitoring and Reporting Program for the project (Attachment 2 to this Addendum). Further, the last three sentences of the IS text above have been revised to read as follows:

A detailed analysis of light and glare at the property line at a height of 3 feet above the ground surface indicates that the residents located adjacent to the baseball field would be exposed to glare of about 8650 candela, which would result in **less-than-significant** glare impacts. No mitigation is required.

3.1 CONCLUSIONS

Based on the information provided above, the newly evaluated impacts of the minor revisions to the lighting plan would result in a decrease in the severity of the glare impacts such that

Mitigation AES-1 is no longer required. The conclusions of this Addendum remain consistent with those made in the IS/MND. No new significant impacts have been identified, nor is the severity of newly identified impacts substantially greater than the conclusions of the IS/MND.

Based upon the evidence included in the above analysis, the proposed project as described in Section 2.0 would not result in a substantial change in the conclusions and analysis included in the IS/MND, and no additional CEQA review is required.

Lighting System

Pole ID	e Summary Pole Height	Mtg Height	Fixture Qty	Luminaire Type	Load	Circuit
A1	80'	80'	4	TLC-LED-1200	4.68 kW	А
		16'	1	TLC-BT-575	0.58 kW	А
		50'	2	TLC-LED-1200	2.34 kW	F
		80'	2	TLC-LED-400	0.80 kW	I
A2	80'	80'	4	TLC-LED-1200	4.68 kW	А
		16'	1	TLC-BT-575	0.58 kW	A
		80'	2	TLC-LED-400	0.80 kW	1
A3	60'	60'	3	TLC-LED-900	2.67 kW	С
		16'	1	TLC-BT-575	0.58 kW	C
		50'	1	TLC-LED-600	0.58 kW	С
		60'	2	TLC-LED-400	0.80 kW	
A4	60'	60'	1	TLC-LED-1200	1.17 kW	В
/		60'	2	TLC-LED-900	1.78 kW	B
		16'	1	TLC-BT-575	0.58 kW	В
		50'	1	TLC-LED-1200	1.17 kW	B
		60'	2	TLC-LED-400	0.80 kW	
A5	60'	60'	1	TLC-LED-1200	1.17 kW	 E
		60'	2	TLC-LED-900	1.78 kW	E
		16'	1	TLC-BT-575	0.58 kW	E
A6	60'	60'	1	TLC-LED-1200	1.17 kW	 D
7.0	00	60'	2	TLC-LED-900	1.78 kW	D
		16'	1	TLC-BT-575	0.58 kW	D
B1-B2	90'	90'	4	TLC-LED-1500	5.72 kW	A
01.02		90'	2	TLC-LED-900	1.78 kW	A
		16'	1	TLC-BT-575	0.58 kW	A
		50'	1	TLC-LED-900	0.89 kW	A
		90'	1	TLC-LED-400	0.40 kW	1
B3	70'	70'	4	TLC-LED-1200	4.68 kW	с С
55	10	70'	2	TLC-LED-1200	2.34 kW	E
		20'	1	TLC-BT-575	0.58 kW	C
		50'	1	TLC-LED-600	0.58 kW	E
		70'	1	TLC-LED-400	0.30 KW	L
B4	80'	80'	5	TLC-LED-1200	5.85 kW	C
04	00	80'	1	TLC-LED-400	0.40 kW	<u> </u>
		16'	1	TLC-LED-400	0.40 kW	і С
B6	70'	70'	3	TLC-LED-1200	3.51 kW	E
00	70	16'	1	TLC-LED-1200	0.58 kW	E
		60'	1	TLC-LED-600	0.58 kW	
B7	70'	70'	6	TLC-LED-000	7.02 kW	E
01	10	16'	1	TLC-BT-575	0.58 kW	E
C1	70'	70'	3	TLC-LED-1500	4.29 kW	A
01	70	70	2	TLC-LED-1300		
		16'	2	TLC-LED-900 TLC-BT-575	1.78 kW 1.15 kW	A A
<u></u>	701					
C2	70'	70' 70'	1 6	TLC-LED-1500 TLC-LED-900	1.43 kW 5.34 kW	A A
D1 D4	50'	16' 50'	2 2	TLC-BT-575	1.15 kW	A
P1-P4	50			TLC-LED-600	1.16 kW	J
		40'	1 112	TLC-LED-400	0.40 kW	К

Poles A1 and A2 are slightly inside of glare zones for the baseball field.

From Hometown to Professional





Not to be reproduced in whole or part without the written consent of Musco Sports Lighting, LLC. ©1981, 2021 Musco Sports Lighting, LLC.




Circuit Summ	hary		
Circuit	Description	Load	Fixture Qty
A	Baseball	43.58 kW	42
В	Softball 1	4.7 kW	5
С	SB1/SO	15.51 kW	16
D	Softball 2	3.53 kW	4
E	SB2/SO	18.13 kW	18
F	BB Batting Cage	2.34 kW	2
I	BB/SB Egress	5.38 kW	13
J	Pool	4.64 kW	8
К	Pool Egress	1.6 kW	4

Fixture Type Summary							
Туре	Source	Wattage	Lumens	L90	L80	L70	Quantity
TLC-LED-1200	LED 5700K - 75 CRI	1170W	136,000	>120,000	>120,000	>120,000	34
TLC-BT-575	LED 5700K - 75 CRI	575W	52,000	>120,000	>120,000	>120,000	16
TLC-LED-400	LED 5700K - 75 CRI	400W	46,500	>120,000	>120,000	>120,000	16
TLC-LED-900	LED 5700K - 75 CRI	890W	89,600	>120,000	>120,000	>120,000	23
TLC-LED-1500	LED 5700K - 75 CRI	1430W	160,000	>120,000	>120,000	>120,000	12
TLC-LED-600	LED 5700K - 75 CRI	580W	65,600	>120,000	>120,000	>120,000	11

Light Level Summary

alculation Grid Summary	/							
Grid Name	Calculation Metric	Ave	Min	Illumination Max	Max/Min	Ave/Min	Circuits	Fixture Qty
Baseball Batting Cage	Horizontal Illuminance	32.8	20	41	2.03	1.64	F	2
Baseball Bullpen 1	Horizontal	30.2	18	38	2.08	1.68	A	42
Baseball Bullpen 2	Horizontal	29.8	10	44	4.49	2.98	A	42
Baseball (Infield)	Horizontal Illuminance	50.4	41	68	1.67	1.23	A	42
Baseball (Outfield)	Horizontal Illuminance	30.9	17	39	2.37	1.82	А	42
Lower Egress Pathway	Horizontal	3.44	1	6	5.94	3.44	I	13
Pool Bleacher 1 - Egress	Horizontal	10.2	6	14	2.52	1.69	К	4
Pool Bleacher 2 - Egress	Horizontal	4.88	4	6	1.58	1.22	к	4
Pool Deck - Egress	Horizontal	7.83	1	16	26.97	7.83	к	4
Pool Deck	Horizontal	20	3	38	12.29	6.65	J	8
Pool	Horizontal Illuminance	30.8	26	37	1.40	1.18	J	8
Property Line Spill @ 10	Max Candela (by Fixture)	25365	14.1	203956	14512.49	1805.35	A,B,C,D,E, F,I,J,K	112
Property Line Spill @ 10	Max Vertical Illuminance Metric	4.88	0	55.5	0.00		A,B,C,D,E, F,I,J,K	112
Property Line Spill @ 15	Max Candela (by Fixture)	19303	450	198199	440.55	42.91	A,B,C,D,E, F,I,J,K	112
Property Line Spill @ 15	Max Vertical Illuminance Metric	3.90	0.01	53.4	10207.17	390.45	A,B,C,D,E, F,I,J,K	112
Property Line Spill @ 5	Max Candela (by Fixture)	29776	9.19	222474	24197.95	3240.07	A,B,C,D,E, F,I,J,K	112
Property Line Spill @ 5	Max Vertical Illuminance Metric	5.04	0	52	0.00		A,B,C,D,E, F,I,J,K	112
Property Line Spill	Max Candela (by Fixture)	34413	8.10	244871	30227.26	4248.51	A,B,C,D,E, F,I,J,K	112
Property Line Spill	Max Vertical Illuminance Metric	5.15	0	47	0.00		A,B,C,D,E, F,I,J,K	112
Soccer	Horizontal Illuminance	35.7	20	48	2.42	1.78	C,E	34
Softball 1 (Infield)	Horizontal Illuminance	50.7	40	64	1.62	1.27	B,C	21
Softball 1 (Outfield)	Horizontal Illuminance	30.1	18	43	2.35	1.67	B,C	21
Softball 2 (Infield)	Horizontal Illuminance	51.2	36	67	1.88	1.42	E,D	22
Softball 2 (Outfield)	Horizontal Illuminance	31.2	19	45	2.30	1.64	E,D	22
Softball Bullpen 1	Horizontal	26.7	17	33	1.96	1.57	С	16
Softball Bullpen 2	Horizontal	34.4	28	40	1.42	1.23	E	18
Softball Bullpen 3	Horizontal	30.9	15	43	2.77	2.06	В	5







Not to be reproduced in whole or part without the written consent of Musco Sports Lighting, LLC. ©1981, 2021 Musco Sports Lighting, LLC.


PROJECT SUMMARY

Mills High School Baseball Softball Pool Millbrae,CA Calculation Grid Summary Illumination Grid Name Calculation Metric Min Max/Min Ave/Min Spill Horizontal 0.20 0 3.17 0.00

Spill	Horizontal	0.20	0	3.17	0.00		A,B,C,D,E, F,I,J,K	112
Spill	Max Candela (by Fixture)	2780	0	8644	0.00		A,B,C,D,E, F,I,J,K	112
Spill	Max Vertical Illuminance Metric	0.27	0	3.35	0.00		A,B,C,D,E, F,I,J,K	112
Upper Pathway Egress	Horizontal	5.64	1	15	18.12	5.64	I	13

Circuits

Fixture Qty







Not to be reproduced in whole or part without the written consent of Musco Sports Lighting, LLC. ©1981, 2021 Musco Sports Lighting, LLC.

PROJECT SUMMARY



Mills High School Baseball Softball Pool Millbrae,CA

1	GRID SUMMARY			
	Name: Size: Spacing:	Baseball Irregular 303 30.0' x 30.0' 3.0' above g		
1	ILLUMINATION SU	JMMARY		
The second	MAINTAINED HORIZONTA			
and the		Infield	Outfield	
and the second	Guaranteed Average:	50	30	
	Scan Average:	50.39	30.94	
12	Maximum:	68	39	
	Minimum:	41	17	
all the	Avg / Min:	1.24	1.87	
and the second s	Guaranteed Max / Min:	2	2.5	
	Max / Min:	1.67	2.37	
1. 2. 1	UG (adjacent pts):	1.29	1.77	
and a	CU:	0.74		
	No. of Points:	25	83	
	LUMINAIRE INFORMATIO	N		
-	Applied Circuits:	А		
- [No. of Luminaires:	42		
	Total Load:	43.58 kW		

Guaranteed Performance: The ILLUMINATION described above is guaranteed per your Musco Warranty document and includes a 0.95 dirt depreciation factor.

Field Measurements: Individual field measurements may vary from computer-calculated predictions and should be taken in accordance with IESNA RP-6-15.

Electrical System Requirements: Refer to Amperage Draw Chart and/or the "Musco Control System Summary" for electrical sizing.


Installation Requirements: Results assume ± 3% nominal voltage at line side of the driver and structures located within 3 feet (1m) of design locations.



Not to be reproduced in whole or part without the written consent of Musco Sports Lighting, LLC. ©1981, 2021 Musco Sports Lighting, LLC.

100





to 0,0 reference point(s) \otimes

Mills High School Baseball Softball Pool Millbrae,CA

GRID SUMMARY	
Name:	Baseball Bullpen 1
Size:	Irregular 303' / 353' / 303'
Spacing:	10.0' x 10.0'
Height:	0.0' above grade
ILLUMINATION S	UMMARY
MAINTAINED HORIZONTA	- AL FOOTCANDLES
	Entire Grid
Scan Average:	30.17
Maximum:	38
Minimum:	18
Avg / Min:	1.66
Max / Min:	2.08
UG (adjacent pts):	1.46
CU:	0.01
No. of Points:	17
LUMINAIRE INFORMATIO	N
Applied Circuits:	Α
No. of Luminaires:	42
Total Load:	43.58 kW

Guaranteed Performance: The ILLUMINATION described above is guaranteed per your Musco Warranty document and includes a 0.95 dirt depreciation factor.

Field Measurements: Individual field measurements may vary from computer-calculated predictions and should be taken in accordance with IESNA RP-6-15.

Electrical System Requirements: Refer to Amperage Draw Chart and/or the "Musco Control System Summary" for electrical sizing.

Installation Requirements: Results assume ± 3% nominal voltage at line side of the driver and structures located within 3 feet (1m) of design locations.



Not to be reproduced in whole or part without the written consent of Musco Sports Lighting, LLC. ©1981, 2021 Musco Sports Lighting, LLC.



100



Mills High School Baseball Softball Pool Millbrae,CA

GRID SUMMARY	
Name:	Baseball Bullpen 2
Size:	Irregular 303' / 353' / 303'
Spacing:	10.0' x 10.0'
Height:	0.0' above grade
ILLUMINATION S	UMMARY
MAINTAINED HORIZONTA	AL FOOTCANDLES
	Entire Grid
Scan Average:	29.76
Maximum:	44
Minimum:	10
Avg / Min:	3.05
Max / Min:	4.49
UG (adjacent pts):	1.69
CU:	0.01
No. of Points:	18
LUMINAIRE INFORMATIO	N
Applied Circuits:	Α
No. of Luminaires:	42
Total Load:	43.58 kW

Guaranteed Performance: The ILLUMINATION described above is guaranteed per your Musco Warranty document and includes a 0.95 dirt depreciation factor.


Field Measurements: Individual field measurements may vary from computer-calculated predictions and should be taken in accordance with IESNA RP-6-15.

Electrical System Requirements: Refer to Amperage Draw Chart and/or the "Musco Control System Summary" for electrical sizing.

Installation Requirements: Results assume ± 3% nominal voltage at line side of the driver and structures located within 3 feet (1m) of design locations.



Not to be reproduced in whole or part without the written consent of Musco Sports Lighting, LLC. ©1981, 2021 Musco Sports Lighting, LLC.



Mills High School Baseball Softball Pool Millbrae,CA

GRID SUMMARY			
Spacing:	200'/200'/200' - basepath 60'		
ILLUMINATION S	UMMARY		
MAINTAINED HORIZONTA	L FOOTCANDL	ES	
	Infield	Outfield	
Guaranteed Average:	50	30	
Scan Average:	50.66	30.11	
Maximum:	64	43	
Minimum:	40	18	
Avg / Min:	1.28	1.64	
Guaranteed Max / Min:	2	2.5	
Max / Min:	1.62	2.35	
UG (adjacent pts):	1.35	1.64	
CU:	0.63		
No. of Points:	25	71	
LUMINAIRE INFORMATIO	N		
Applied Circuits:	В, С		
No. of Luminaires:	21		
Total Load:	20.2 kW		

Guaranteed Performance: The ILLUMINATION described above is guaranteed per your Musco Warranty document and includes a 0.95 dirt depreciation factor.


Field Measurements: Individual field measurements may vary from computer-calculated predictions and should be taken in accordance with IESNA RP-6-15.

Electrical System Requirements: Refer to Amperage Draw Chart and/or the **"Musco Control System Summary"** for electrical sizing.

Installation Requirements: Results assume \pm 3% nominal voltage at line side of the driver and structures located within 3 feet (1m) of design locations.



Not to be reproduced in whole or part without the written consent of Musco Sports Lighting, LLC. ©1981, 2021 Musco Sports Lighting, LLC.



GRID SUMMARY	
Name:	Softball Bullpen 1
Size:	200'/200'/200' - basepath 60'
Spacing:	10.0' x 10.0'
Height:	0.0' above grade
ILLUMINATION S	UMMARY
MAINTAINED HORIZONTA	
	Entire Grid
Scan Average:	26.70
Maximum:	33
Minimum:	17
Avg / Min:	1.60
Max / Min:	1.96
UG (adjacent pts):	1.32
CU:	0.02
No. of Points:	14
LUMINAIRE INFORMATIO	N
Applied Circuits:	С
No. of Luminaires:	16
Total Load:	15.51 kW

Guaranteed Performance: The ILLUMINATION described above is guaranteed per your Musco Warranty document and includes a 0.95 dirt depreciation factor.

Field Measurements: Individual field measurements may vary from computer-calculated predictions and should be taken in accordance with IESNA RP-6-15.


Electrical System Requirements: Refer to Amperage Draw Chart and/or the "Musco Control System Summary" for electrical sizing.

Installation Requirements: Results assume ± 3% nominal voltage at line side of the driver and structures located within 3 feet (1m) of design locations.



Not to be reproduced in whole or part without the written consent of Musco Sports Lighting, LLC. ©1981, 2021 Musco Sports Lighting, LLC.

179



GRID SUMMARY	
Name:	Softball Bullpen 2
Size:	200'/200'/200' - basepath 60'
Spacing:	10.0' x 10.0'
Height:	0.0' above grade
ILLUMINATION S	
MAINTAINED HORIZONTA	
	Entire Grid
Scan Average:	34.41
Maximum:	40
Minimum:	28
Avg / Min:	1.22
Max / Min:	1.42
UG (adjacent pts):	1.17
CU:	0.02
No. of Points:	12
LUMINAIRE INFORMATIO	N
Applied Circuits:	E
No. of Luminaires:	18
Total Load:	18.13 kW

Guaranteed Performance: The ILLUMINATION described above is guaranteed per your Musco Warranty document and includes a 0.95 dirt depreciation factor.

Field Measurements: Individual field measurements may vary from computer-calculated predictions and should be taken in accordance with IESNA RP-6-15.


Electrical System Requirements: Refer to Amperage Draw Chart and/or the "Musco Control System Summary" for electrical sizing.

Installation Requirements: Results assume ± 3% nominal voltage at line side of the driver and structures located within 3 feet (1m) of design locations.



Not to be reproduced in whole or part without the written consent of Musco Sports Lighting, LLC. ©1981, 2021 Musco Sports Lighting, LLC.





GRID SUMMARY	
Name:	Softball Bullpen 3
Size:	200'/200'/200' - basepath 60'
Spacing:	10.0' x 10.0'
Height:	0.0' above grade
ILLUMINATION S	IMMARY
MAINTAINED HORIZONTA	
	Entire Grid
Scan Average:	30.87
Maximum:	43
Minimum:	15
Avg / Min:	2.00
Max / Min:	2.77
UG (adjacent pts):	1.39
CU:	0.09
No. of Points:	14
LUMINAIRE INFORMATIO	N
Applied Circuits:	В
No. of Luminaires:	5
Total Load:	4.7 kW

Guaranteed Performance: The ILLUMINATION described above is guaranteed per your Musco Warranty document and includes a 0.95 dirt depreciation factor.


Field Measurements: Individual field measurements may vary from computer-calculated predictions and should be taken in accordance with IESNA RP-6-15.

Electrical System Requirements: Refer to Amperage Draw Chart and/or the "Musco Control System Summary" for electrical sizing.

Installation Requirements: Results assume ± 3% nominal voltage at line side of the driver and structures located within 3 feet (1m) of design locations.



Not to be reproduced in whole or part without the written consent of Musco Sports Lighting, LLC. ©1981, 2021 Musco Sports Lighting, LLC.



to 0,0 reference point(s) \otimes

Mills High School Baseball Softball Pool Millbrae,CA

GRID SUMMARY							
Size: Spacing:	Softball 2 180'/180'/180' - basepath 60' 20.0' x 20.0' 3.0' above grade						
ILLUMINATION SUMMARY							
MAINTAINED HORIZONTA	L FOOTCANDL	ES					
	Infield	Outfield					
Guaranteed Average:	50	30					
Scan Average:	51.24	31.18					
Maximum:	67	45					
Minimum:	36	19					
Avg / Min:	1.44	1.61					
Guaranteed Max / Min:	2	2.5					
Max / Min:	1.88	2.30					
UG (adjacent pts):	1.30	1.59					
CU:	0.51						
No. of Points:	25	56					
LUMINAIRE INFORMATIO	N						
Applied Circuits:							
No. of Luminaires:							
Total Load:	21.65 kW						

Guaranteed Performance: The ILLUMINATION described above is guaranteed per your Musco Warranty document and includes a 0.95 dirt depreciation factor.

Field Measurements: Individual field measurements may vary from computer-calculated predictions and should be taken in accordance with IESNA RP-6-15.

Electrical System Requirements: Refer to Amperage Draw Chart and/or the "Musco Control System Summary" for electrical sizing.

Installation Requirements: Results assume ± 3% nominal voltage at line side of the driver and structures located within 3 feet (1m) of design locations.




Not to be reproduced in whole or part without the written consent of Musco Sports Lighting, LLC. ©1981, 2021 Musco Sports Lighting, LLC.

Pole location(s) \oplus dimensions are relative

5

3

1



60'

120'

EQUIPMENT LIST FOR AREAS SHOWN

to 0,0 reference point(s) \otimes

Mills High School Baseball Softball Pool Millbrae,CA

	GRID SUMMARY	
	Name:	Soccer
		336' x 180'
	Spacing:	30.0' x 30.0'
/	Height:	3.0' above grade
	ILLUMINATION S	UMMARY
	MAINTAINED HORIZONTA	L FOOTCANDLES
ł		Entire Grid
	Guaranteed Average:	30
1	Scan Average:	35.68
	Maximum:	48
	Minimum:	20
	Avg / Min:	1.82
	Guaranteed Max / Min:	2.5
	Max / Min:	2.42
	UG (adjacent pts):	1.81
28	CU:	0.63
	No. of Points:	72
2.54	LUMINAIRE INFORMATIO	
20	Applied Circuits:	-
	No. of Luminaires:	* ·
100	Total Load:	33.63 KW

Guaranteed Performance: The ILLUMINATION described above is guaranteed per your Musco Warranty document and includes a 0.95 dirt depreciation factor.

Field Measurements: Individual field measurements may vary from computer-calculated predictions and should be taken in accordance with IESNA RP-6-15.

Electrical System Requirements: Refer to Amperage Draw Chart and/or the "Musco Control System Summary" for electrical sizing.

Installation Requirements: Results assume ± 3% nominal voltage at line side of the driver and structures located within 3 feet (1m) of design locations.



Not to be reproduced in whole or part without the written consent of Musco Sports Lighting, LLC. ©1981, 2021 Musco Sports Lighting, LLC.

EQU	EQUIPMENT LIST FOR AREAS SHOWN								
	Р	ole			Luminaires				
QTY	LOCATION	SIZE	GRADE ELEVATION	Mounting Height	LUMINAIRE TYPE	QTY / POLE	THIS GRID	OTHER GRIDS	
4	P1-P4	50'	-	40'	TLC-LED-400	1	0	1	
				50'	TLC-LED-600	2	2	0	
4		TOTALS 12 8 4							

		28	29	29	29	30	29	29	59	P1		
		34	31	29	29	31	32	35	-	115		
		34	34 33	32 32	31 31	32 32	34 _34	35 34			Ţ	ALL DATE
T		28	30	30	29	30	32	32		E.	Mage L	
	44 ·	28	27	27	28	29	29	31		E	and the second	
	ttri	28	26	27	28	29	29	30			12=	5192 23
and the state of the	11	28	29	29	30	31	31	30			-	
		30	31	31	31	33	34	32		1	1	77
Canada Contraction		32	32	31	31	34	37	36	1			1.0
Shine To		33	31	30	29	31	34	37	th			1
)	28	28	28	29	30	30	30	59	P2	影力	
5: Poles A1 and A2 are slightly inside of glare zones for the baseball field.	e and a second	7								-		

to 0,0 reference point(s) \otimes

Mills High School Baseball Softball Pool Millbrae,CA

_		
	GRID SUMMARY	
	Name:	Pool
	Size:	67' x 115'
	Spacing:	10.0' x 10.0'
_	Height:	3.0' above grade
	ILLUMINATION SI	UMMARY
	MAINTAINED HORIZONTA	L FOOTCANDLES
		Entire Grid
	Guaranteed Average:	30
	Scan Average:	30.79
	Maximum:	37
	Minimum:	26
	Avg / Min:	1.17
	Guaranteed Max / Min:	2.5
	Max / Min:	1.40
	UG (adjacent pts):	1.24
	CU:	0.50
	No. of Points:	84
	LUMINAIRE INFORMATIO	
	Applied Circuits:	l
	No. of Luminaires:	•
	Total Load:	4.64 kW

Guaranteed Performance: The ILLUMINATION described above is guaranteed per your Musco Warranty document and includes a 0.95 dirt depreciation factor.

Field Measurements: Individual field measurements may vary from computer-calculated predictions and should be taken in accordance with IESNA RP-6-15.

Electrical System Requirements: Refer to Amperage Draw Chart and/or the "Musco Control System Summary" for electrical sizing.

Installation Requirements: Results assume ± 3% nominal voltage at line side of the driver and structures located within 3 feet (1m) of design locations.



Not to be reproduced in whole or part without the written consent of Musco Sports Lighting, LLC. ©1981, 2021 Musco Sports Lighting, LLC.



EQU	EQUIPMENT LIST FOR AREAS SHOWN								
	Р	ole			Luminaires				
QTY	LOCATION	SIZE	GRADE ELEVATION	Mounting Height	LUMINAIRE TYPE	QTY / POLE	THIS GRID	OTHER GRIDS	
4	P1-P4	50'	-	40'	TLC-LED-400	1	0	1	
				50'	TLC-LED-600	2	2	0	
4	TOTALS 12 8 4								



Mills High School Baseball Softball Pool Millbrae,CA

	GRID SUMMARY	
	Name:	Pool Deck
	Size:	67' x 115'
	Spacing:	10.0' x 10.0'
	Height:	3.0' above grade
E.	ILLUMINATION S	IMMARY
<u>B</u>	MAINTAINED HORIZONTA	
		Entire Grid
	Seen Average	19.95
	Scan Average: Maximum:	38
	Minimum:	3
2	Avg / Min:	6.52
	Max / Min:	
	UG (adjacent pts):	
	CU:	0.44
1	No. of Points:	113
	LUMINAIRE INFORMATIO	N
	Applied Circuits:	J
	No. of Luminaires:	8
	Total Load:	4.64 kW

Guaranteed Performance: The ILLUMINATION described above is guaranteed per your Musco Warranty document and includes a 0.95 dirt depreciation factor.

Field Measurements: Individual field measurements may vary from computer-calculated predictions and should be taken in accordance with IESNA RP-6-15.

Electrical System Requirements: Refer to Amperage Draw Chart and/or the "Musco Control System Summary" for electrical sizing.

Installation Requirements: Results assume ± 3% nominal voltage at line side of the driver and structures located within 3 feet (1m) of design locations.



Not to be reproduced in whole or part without the written consent of Musco Sports Lighting, LLC. ©1981, 2021 Musco Sports Lighting, LLC.

EQU	EQUIPMENT LIST FOR AREAS SHOWN								
	Р	ole			Luminaires				
QTY	LOCATION	SIZE	GRADE ELEVATION	Mounting Height	LUMINAIRE TYPE	QTY / POLE	THIS GRID	OTHER GRIDS	
4	P1-P4	50'	0'	40'	TLC-LED-400	1	1	0	
				50'	TLC-LED-600	2	0	2	
4	TOTALS 12 4 8								



Mills High School Baseball Softball Pool Millbrae,CA

CED THE L

GRID SUMMARY Name: Pool Deck - Egress Spacing: 10.0' x 10.0' Height: 3.0' above grade ILLUMINATION SUMMARY MAINTAINED HORIZONTAL FOOTCANDLES Entire Grid Scan Average: 7.83 Maximum: 16 Minimum: 1 Avg / Min: 13.08 Max / Min: 26.97 UG (adjacent pts): 4.53
Spacing: 10.0' x 10.0' Height: 3.0' above grade ILLUMINATION SUMMARY MAINTAINED HORIZONTAL FOOTCANDLES Entire Grid Scan Average: 7.83 Maximum: 16 Minimum: 1 Avg / Min: 13.08 Max / Min: 26.97
Height: 3.0' above grade ILLUMINATION SUMMARY MAINTAINED HORIZONTAL FOOTCANDLES Entire Grid Scan Average: 7.83 Maximum: 16 Minimum: 1 Avg / Min: 13.08 Max / Min: 26.97
ILLUMINATION SUMMARY MAINTAINED HORIZONTAL FOOTCANDLES Entire Grid Scan Average: 7.83 Maximum: 16 Minimum: 1 Avg / Min: 13.08 Max / Min: 26.97
MAINTAINED HORIZONTAL FOOTCANDLES Entire Grid Scan Average: 7.83 Maximum: 16 Minimum: 1 Avg / Min: 13.08 Max / Min: 26.97
Entire Grid Scan Average: 7.83 Maximum: 16 Minimum: 1 Avg / Min: 13.08 Max / Min: 26.97
Scan Average: 7.83 Maximum: 16 Minimum: 1 Avg / Min: 13.08 Max / Min: 26.97
Maximum: 16 Minimum: 1 Avg / Min: 13.08 Max / Min: 26.97
Minimum: 1 Avg / Min: 13.08 Max / Min: 26.97
Avg / Min: 13.08 Max / Min: 26.97
Max / Min: 26.97
LIG (adjacent nts): 4 53
CU: 0.52
No. of Points: 113
LUMINAIRE INFORMATION
Applied Circuits: K
No. of Luminaires: 4
Total Load: 1.6 kW

Guaranteed Performance: The ILLUMINATION described above is guaranteed per your Musco Warranty document and includes a 0.95 dirt depreciation factor.

Field Measurements: Individual field measurements may vary from computer-calculated predictions and should be taken in accordance with IESNA RP-6-15.


Electrical System Requirements: Refer to Amperage Draw Chart and/or the "Musco Control System Summary" for electrical sizing.

Installation Requirements: Results assume ± 3% nominal voltage at line side of the driver and structures located within 3 feet (1m) of design locations.



Not to be reproduced in whole or part without the written consent of Musco Sports Lighting, LLC. ©1981, 2021 Musco Sports Lighting, LLC.







40

20'

Mills High School Baseball Softball Pool Millbrae,CA

GRID SUMMARY	
Name: Spacing:	10.0' × 10.0'
Height:	3.0' above grade
ILLUMINATION S	UMMARY
MAINTAINED HORIZONTA	AL FOOTCANDLES
	Entire Grid
Scan Average:	10.16
Maximum:	14
Minimum:	6
Avg / Min:	1.82
Max / Min:	2.52
UG (adjacent pts):	
CU:	
No. of Points:	6
LUMINAIRE INFORMATIO	
Applied Circuits:	K
No. of Luminaires:	
Total Load:	1.6 kW

Guaranteed Performance: The ILLUMINATION described above is guaranteed per your Musco Warranty document and includes a 0.95 dirt depreciation factor.

Field Measurements: Individual field measurements may vary from computer-calculated predictions and should be taken in accordance with IESNA RP-6-15.

Electrical System Requirements: Refer to Amperage Draw Chart and/or the "Musco Control System Summary" for electrical sizing.

Installation Requirements: Results assume ± 3% nominal voltage at line side of the driver and structures located within 3 feet (1m) of design locations.



Not to be reproduced in whole or part without the written consent of Musco Sports Lighting, LLC. ©1981, 2021 Musco Sports Lighting, LLC.

ALC: UNK ON THE R. L. W.

P2

EQU	EQUIPMENT LIST FOR AREAS SHOWN								
	Р	ole			Luminaires				
QTY	LOCATION	SIZE	GRADE ELEVATION	Mounting Height	LUMINAIRE TYPE	QTY / POLE	THIS GRID	OTHER GRIDS	
4	P1-P4	50'	0'	40'	TLC-LED-400	1	1	0	
				50'	TLC-LED-600	2	0	2	
4	TOTALS							8	



40'

20'

Mills High School Baseball Softball Pool Millbrae,CA

GRID SUMMARY	
Name:	Pool Bleacher 2 - Egress
Spacing:	10.0' x 10.0'
Height:	3.0' above grade
ILLUMINATION S	UMMARY
MAINTAINED HORIZONTA	AL FOOTCANDLES
	Entire Grid
Scan Average:	4.88
Maximum:	6
Minimum:	4
Avg / Min:	1.29
Max / Min:	1.58
UG (adjacent pts):	1.31
CU:	0.02
No. of Points:	6
LUMINAIRE INFORMATIO	N
Applied Circuits:	К
No. of Luminaires:	4
Total Load:	1.6 kW

Guaranteed Performance: The ILLUMINATION described above is guaranteed per your Musco Warranty document and includes a 0.95 dirt depreciation factor.


Field Measurements: Individual field measurements may vary from computer-calculated predictions and should be taken in accordance with IESNA RP-6-15.

Electrical System Requirements: Refer to Amperage Draw Chart and/or the "Musco Control System Summary" for electrical sizing.

Installation Requirements: Results assume ± 3% nominal voltage at line side of the driver and structures located within 3 feet (1m) of design locations.



Not to be reproduced in whole or part without the written consent of Musco Sports Lighting, LLC. ©1981, 2021 Musco Sports Lighting, LLC.





	GRID SUMMARY	
	Name:	erasedBaseball Batting Cage
	Spacing:	10.0' x 10.0'
	Height:	3.0' above grade
	ILLUMINATION SU	UMMARY
	MAINTAINED HORIZONTA	AL FOOTCANDLES
		Entire Grid
	Scan Average:	32.78
	Maximum:	41
<u></u>	Minimum:	20
	Avg / Min:	1.61
1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	Max / Min:	2.03
1. S.	UG (adjacent pts):	1.39
And Personnelling	CU:	0.30
Aug. 1998	No. of Points:	16
	LUMINAIRE INFORMATIO	
and the second second	Applied Circuits:	F
and the second se	No. of Luminaires:	2
and the second second	Total Load:	2.34 kW
	is guaranteed per your M includes a 0.95 dirt depr Field Measurements: In from computer-calculate in accordance with IESN	ndividual field measurements may vary ed predictions and should be taken
L		"Musco Control System Summary"
		its: Results assume ± 3% side of the driver and structures n) of design locations.



Not to be reproduced in whole or part without the written consent of Musco Sports Lighting, LLC. ©1981, 2021 Musco Sports Lighting, LLC.



Pole location(s) \oplus dimensions are relative to 0,0 reference point(s) \otimes

ENGINEERED DESIGN By: H.Sabers · File #201284N · 06-Apr-21

100

Mills High School Baseball Softball Pool Millbrae,CA

6	GRID SUMMARY	
	Name: Spacing:	Lower Egress Pathway 20.0' x 20.0'
	-10	0.0' above grade
	LLUMINATION SU	JMMARY
N	MAINTAINED HORIZONTA	L FOOTCANDLES
		Entire Grid
	Scan Average:	3.44
2	Maximum:	6
	Minimum:	1
	Avg / Min:	3.36
8	Max / Min:	5.94
	UG (adjacent pts):	2.22
	CU:	0.20
	No. of Points:	89
L	UMINAIRE INFORMATIO	N
7	Applied Circuits:	I
		13
	Total Load:	5.38 kW

Guaranteed Performance: The ILLUMINATION described above is guaranteed per your Musco Warranty document and includes a 0.95 dirt depreciation factor.

Field Measurements: Individual field measurements may vary from computer-calculated predictions and should be taken in accordance with IESNA RP-6-15.

Electrical System Requirements: Refer to Amperage Draw Chart and/or the "Musco Control System Summary" for electrical sizing.

Installation Requirements: Results assume ± 3% nominal voltage at line side of the driver and structures located within 3 feet (1m) of design locations.



Not to be reproduced in whole or part without the written consent of Musco Sports Lighting, LLC. ©1981, 2021 Musco Sports Lighting, LLC.



-

	_	_	_	_	_						
18	EQUIP		IST FOF Pole	R AREAS SH	HOWN	Luminaire	5	-	-		
		LOCATION	SIZE	GRADE	MOUNTING HEIGHT	LUMINAIRE TYPE	QTY / POLE	THIS GRID	OTHER GRIDS		
	1	A1	80'	0'	80' 15.48'	TLC-LED-400 TLC-BT-575	2* 1	2	0 1		
					50' 80'	TLC-LED-1200 TLC-LED-1200	2	0	2 4		
	1	A2	80'	0'	80' 15.48'	TLC-LED-400 TLC-BT-575	2* 1	2	0		
	_				80'	TLC-LED-1200	4	0	4		
	1	A3	60'	0'	60' 15.5'	TLC-LED-400 TLC-BT-575	2* 1	2 0	0 1		
					50' 60'	TLC-LED-600 TLC-LED-900	1	0	1 3		
	1	A4	60'	0'	60' 60'	TLC-LED-900 TLC-LED-400	2 2*	02	2 0		
					15.5' 50'	TLC-BT-575 TLC-LED-1200	1	0	1 1		
	1	B1	90'	0'	60' 90'	TLC-LED-1200 TLC-LED-900	1	0	1 2		R
	1	51		Ŭ	90' 15.48'	TLC-LED-400 TLC-BT-575	1*	1 0	0		E
					50'	TLC-LED-900	1	0	1 1		
	1	B2	90'	0'	90' 90'	TLC-LED-1500 TLC-LED-1500	4	0	4		-
					90' 15.48'	TLC-LED-400 TLC-BT-575	1* 1	1	0 1		-
					50' 90'	TLC-LED-900 TLC-LED-900	1 2	0 0	1 2		4
	1	B3	70'	0'	70' 20'	TLC-LED-400 TLC-BT-575	1* 1	1 0	0 1	Carlo in a second a second and a second	Saltste
					50' 70'	TLC-LED-600 TLC-LED-1200	1 6	0	1 6		
	1	B4	80'	0'	80' 15.5'	TLC-LED-400 TLC-BT-575	1	1 0	0 1	3.4 7.0 10 58 4 4 5 14 4 4 7.1 8.1 6.2 4.0 2.7 1.9 2.2 3.4 4.4 5.7 5.3 4.1 2.8 1.6 0.9	
	1	B6	70'	0'	80' 15.5'	TLC-LED-1200 TLC-BT-575	5	0	5	A_3 A_4 A_5 A_4 A_5 A_4 A_5 A_4 A_5 A_6	-
					60' 70'	TLC-LED-600 TLC-LED-1200	1	1	0 3	67 10 713 813 08 8 30 6 β 1/8 7 8 6 3 41 27 38 48 68 64 67 58 44 2.9 1.7 β.9	
	9 This stru	cture utilize	s a back-to	TOTALS	s ng configuration		69	13	56	10.1	2
		les A1 and		ightly inside o							
			IN FEE	T 1 : 100 100'		200'				Pole location(s) + to 0,0 reference po	+ dim oint(s)
1		U		100		200					

to 0,0 reference point(s) \otimes

Mills High School Baseball Softball Pool Millbrae,CA

GRID SUMMARY	
Name:	Upper Pathway Egress
Spacing:	20.0' x 20.0'
Height:	3.0' above grade
ILLUMINATION S	UMMARY
MAINTAINED HORIZONTA	L FOOTCANDLES
	Entire Grid
Scan Average:	5.64
Maximum:	15
Minimum:	1
Avg / Min:	6.70
Max / Min:	18.12
UG (adjacent pts):	4.36
CU:	0.28
No. of Points:	76
LUMINAIRE INFORMATIO	N
Applied Circuits:	I
No. of Luminaires:	13
Total Load:	5.38 kW

Guaranteed Performance: The ILLUMINATION described above is guaranteed per your Musco Warranty document and includes a 0.95 dirt depreciation factor.

Field Measurements: Individual field measurements may vary from computer-calculated predictions and should be taken in accordance with IESNA RP-6-15.

Electrical System Requirements: Refer to Amperage Draw Chart and/or the "Musco Control System Summary" for electrical sizing.

Installation Requirements: Results assume ± 3% nominal voltage at line side of the driver and structures located within 3 feet (1m) of design locations.



Not to be reproduced in whole or part without the written consent of Musco Sports Lighting, LLC. ©1981, 2021 Musco Sports Lighting, LLC.

dimensions are relative


F F

R

240

120'

Pole location(s) \oplus dimensions are relative to 0,0 reference point(s) \otimes



Mills High School Baseball Softball Pool Millbrae,CA

	GRID SUMMARY	
	Name:	Spill
	Spacing:	30.0'
	Height:	3.0' above grade
	ILLUMINATION SU	UIVIIVIARY
	HORIZONTAL FOOTCANDI	LES
		Entire Grid
	Scan Average:	0.2024
	Maximum:	3.17
-	Minimum:	0.00
and states	No. of Points:	87
1945	LUMINAIRE INFORMATIO	N
- 1	Applied Circuits:	A, B, C, D, E, F, I, J, K
and the	No. of Luminaires:	112
	Total Load:	99.39 kW

Guaranteed Performance: The ILLUMINATION described above is guaranteed per your Musco Warranty document.

Field Measurements: Individual field measurements may vary from computer-calculated predictions and should be taken in accordance with IESNA RP-6-15.

Electrical System Requirements: Refer to Amperage Draw Chart and/or the **"Musco Control System Summary"** for electrical sizing.

Installation Requirements: Results assume \pm 3% nominal voltage at line side of the driver and structures located within 3 feet (1m) of design locations.






Not to be reproduced in whole or part without the written consent of Musco Sports Lighting, LLC. ©1981, 2021 Musco Sports Lighting, LLC.

240

120'

SCALE IN FEET 1:120

to 0,0 reference point(s) \otimes



Mills High School Baseball Softball Pool Millbrae,CA

	GRID SUMMARY	
	Name:	Spill
	Spacing:	30.0'
	Height:	3.0' above grade
	ILLUMINATION SU	UMMARY
	MAX VERTICAL FOOTCAN	DLES
1		Entire Grid
	Scan Average:	0.2667
1	Maximum:	3.35
-	Minimum:	0.00
times of the	No. of Points:	87
1	LUMINAIRE INFORMATIO	N
and V	Applied Circuits:	A, B, C, D, E, F, I, J, K
Aller The	No. of Luminaires:	112
	Total Load:	99.39 kW

Guaranteed Performance: The ILLUMINATION described above is guaranteed per your Musco Warranty document.

Field Measurements: Individual field measurements may vary from computer-calculated predictions and should be taken in accordance with IESNA RP-6-15.

Electrical System Requirements: Refer to Amperage Draw Chart and/or the "Musco Control System Summary" for electrical sizing.

Installation Requirements: Results assume ± 3% nominal voltage at line side of the driver and structures located within 3 feet (1m) of design locations.



Not to be reproduced in whole or part without the written consent of Musco Sports Lighting, LLC. ©1981, 2021 Musco Sports Lighting, LLC.



240

120'

SCALE IN FEET 1:120

to 0,0 reference point(s) \otimes



Mills High School Baseball Softball Pool Millbrae,CA

	GRID SUMMARY	
	Name:	Spill
	Spacing:	30.0'
	Height:	3.0' above grade
	ILLUMINATION SU	JIMIMARY
	CANDELA (PER FIXTURE)	
the part of the second		Entire Grid
	Scan Average:	2780.1143
the second	Maximum:	8643.89
-	Minimum:	0.00
California State	No. of Points:	87
19	LUMINAIRE INFORMATIO	N
- 7	Applied Circuits:	A, B, C, D, E, F, I, J, K
Alter the	No. of Luminaires:	112
	Total Load:	99.39 kW

Guaranteed Performance: The ILLUMINATION described above is guaranteed per your Musco Warranty document.

Field Measurements: Individual field measurements may vary from computer-calculated predictions and should be taken in accordance with IESNA RP-6-15.

Electrical System Requirements: Refer to Amperage Draw Chart and/or the "Musco Control System Summary" for electrical sizing.

Installation Requirements: Results assume ± 3% nominal voltage at line side of the driver and structures located within 3 feet (1m) of design locations.



Not to be reproduced in whole or part without the written consent of Musco Sports Lighting, LLC. ©1981, 2021 Musco Sports Lighting, LLC.




Pole location(s) \oplus dimensions are relative

240

120'

Pole location(s) \oplus dimensions are relative to 0,0 reference point(s) \otimes



Mills High School Baseball Softball Pool Millbrae,CA

	GRID SUMMARY			
		Property Line Spill 30.0' 3.4' above grade		
	ILLUMINATION SU	UMMARY		
	MAX VERTICAL FOOTCAN	DLES		
		Entire Grid		
	Scan Average:	5.1499		
	Maximum:	47.00		
-	Minimum:	0.00		
3.23	No. of Points:	66		
1999	LUMINAIRE INFORMATIO	N		
. 7	Applied Circuits:	A, B, C, D, E, F, I, J, K		
the second	No. of Luminaires:	112		
9	Total Load:	99.39 kW		

Guaranteed Performance: The ILLUMINATION described above is guaranteed per your Musco Warranty document.

Field Measurements: Individual field measurements may vary from computer-calculated predictions and should be taken in accordance with IESNA RP-6-15.

Electrical System Requirements: Refer to Amperage Draw Chart and/or the **"Musco Control System Summary"** for electrical sizing.

Installation Requirements: Results assume \pm 3% nominal voltage at line side of the driver and structures located within 3 feet (1m) of design locations.




Not to be reproduced in whole or part without the written consent of Musco Sports Lighting, LLC. ©1981, 2021 Musco Sports Lighting, LLC.

imensions are relative (s) ⊗ No



240

120'



Mills High School Baseball Softball Pool Millbrae,CA

GRID SUMMARY	
Name:	Property Line Spill
Spacing:	30.0'
Height:	3.4' above grade
ILLUMINATION S	IMMARY
	SIMMART
CANDELA (PER FIXTURE)	
	Entire Grid
Scan Average:	34412.8750
Maximum:	244870.83
Minimum:	8.10
No. of Points:	66
LUMINAIRE INFORMATIO	N
Applied Circuits:	A, B, C, D, E, F, I, J, K
No. of Luminaires:	112
Total Load:	99.39 kW

Guaranteed Performance: The ILLUMINATION described above is guaranteed per your Musco Warranty document.

Field Measurements: Individual field measurements may vary from computer-calculated predictions and should be taken in accordance with IESNA RP-6-15.

Electrical System Requirements: Refer to Amperage Draw Chart and/or the "Musco Control System Summary" for electrical sizing.

Installation Requirements: Results assume ± 3% nominal voltage at line side of the driver and structures located within 3 feet (1m) of design locations.




Not to be reproduced in whole or part without the written consent of Musco Sports Lighting, LLC. ©1981, 2021 Musco Sports Lighting, LLC.

Pole location(s) \oplus dimensions are relative to 0,0 reference point(s) \otimes

240

120'

Pole location(s) \oplus dimensions are relative to 0,0 reference point(s) \otimes



Mills High School Baseball Softball Pool Millbrae,CA

	GRID SUMMARY			
		Property Line Spill 30.0' 3.4' above grade		
	ILLUMINATION SU	UMMARY		
	HORIZONTAL FOOTCAND	LES		
		Entire Grid		
	Scan Average:	3.4302		
- 1	Maximum:	30.41		
-	Minimum:	0.00		
100	No. of Points:	66		
17	LUMINAIRE INFORMATIO	N		
1. 12	Applied Circuits:	A, B, C, D, E, F, I, J, K		
the state	No. of Luminaires:	112		
	Total Load:	99.39 kW		

Guaranteed Performance: The ILLUMINATION described above is guaranteed per your Musco Warranty document.

Field Measurements: Individual field measurements may vary from computer-calculated predictions and should be taken in accordance with IESNA RP-6-15.


Electrical System Requirements: Refer to Amperage Draw Chart and/or the **"Musco Control System Summary"** for electrical sizing.

Installation Requirements: Results assume \pm 3% nominal voltage at line side of the driver and structures located within 3 feet (1m) of design locations.



Not to be reproduced in whole or part without the written consent of Musco Sports Lighting, LLC. ©1981, 2021 Musco Sports Lighting, LLC.

t(s) ⊗



SCALE IN FEET 1 : 120

Pole location(s) \oplus dimensions are relative to 0,0 reference point(s) \otimes

120' **ENGINEERED DESIGN** By: H.Sabers · File #201284N · 06-Apr-21

240'

Mills High School Baseball Softball Pool Millbrae,CA

EQUIPMENT LAYOUT

- INCLUDES: Baseball
- · Pool
- · Soccer · Softball 1
- Softball 2

Electrical System Requirements: Refer to Amperage Draw Chart and/or the "Musco Control System Summary" for electrical sizing.

Installation Requirements: Results assume ± 3% nominal voltage at line side of the driver and structures located within 3 feet (1m) of design locations.

EQ	UIPME	NT LIST	FOR AR	EAS SHO	OWN	
		Pole			Luminaires	
QTY	LOCATION	CLASS	GRADE	MOUNTING	LUMINAIRE	QTY/
			ELEVATION	HEIGHT	TYPE	POLE
1	A1	LSS80A	-	80'	TLC-LED-400	2*
				15.5'	TLC-BT-575	1
				50'	TLC-LED-1200	2
				80'	TLC-LED-1200	4
1	A2	LSS80A	-	80'	TLC-LED-400	2*
				15.5'	TLC-BT-575	1
				80'	TLC-LED-1200	4
1	A3	LSS60B	-	60'	TLC-LED-400	2*
				15.5'	TLC-BT-575	1
				50'	TLC-LED-600	1
				60'	TLC-LED-900	3
1	A4	LSS60B	-	60'	TLC-LED-900	2
				60'	TLC-LED-400	2*
				15.5'	TLC-BT-575	1
				50'	TLC-LED-1200	1
				60'	TLC-LED-1200	1
1	A5	LSS60A	-	60'	TLC-LED-1200	1
				15.5'	TLC-BT-575	1
				60'	TLC-LED-900	2
1	A6	LSS60A	0'	60'	TLC-LED-1200	1
				15.5'	TLC-BT-575	1
				60'	TLC-LED-900	2
1	B1	LSS90A	-	90'	TLC-LED-900	2
				90'	TLC-LED-400	1*
				15.5'	TLC-BT-575	1
				50'	TLC-LED-900	1
				90'	TLC-LED-1500	4
1	B2	LSS90A	-	90'	TLC-LED-1500	4
				90'	TLC-LED-400	1*
				15.5'	TLC-BT-575	1
				50'	TLC-LED-900	1
				90'	TLC-LED-900	2
1	B3	LSS70C	-	70'	TLC-LED-400	1*
-	55	200700		20'	TLC-BT-575	1
				50'	TLC-LED-600	1
				70'	TLC-LED-1200	6
1	B4	LSS80B	-	80'	TLC-LED-400	1
-	54	100000		15.5'	TLC-BT-575	1
				80'	TLC-LED-1200	5
1	B6	LSS70C		15.5'	TLC-BT-575	1
1	во	L3370C	-	60'	TLC-LED-600	1
				70'	TLC-LED-1200	3
1	B7	LSS70C	-	15.5'	TLC-BT-575	1
-	57	133700		70'	TLC-LED-1200	6
1	C1	LSS70C		70	TLC-LED-1200 TLC-LED-900	2
-	C1	L33/0C	-	15.5'	TLC-BT-575	2
						2
1	C2	100700		70'	TLC-LED-1500	1
1	L2	LSS70D	-		TLC-LED-1500	
				15.5'	TLC-BT-575	2
		100505		70'	TLC-LED-900	6
4	P1-P4	LSS50B	-	40'	TLC-LED-400	1
10				50'	TLC-LED-600	2
18	a atmt	utilian !	TOTAL		configuration	112

This structure utilizes a back-to-back mounting configuration

SINGLE LUMINAIRE AMPERAGE DRAW CHART										
Ballast Specifications (.90 min power factor)	Line Amperage Per Luminaire (max draw)									
Single Phase Voltage	208 (60)	220 (60)	240 (60)	277 (60)	347 (60)	380 (60)	480 (60)			
TLC-LED-1200	7.0	6.6	6.1	5.2	4.2	4.0	3.0			
TLC-LED-400	2.3	2.2	<mark>/</mark> 2.0	1.7	1.4	1.3	1.0			
TLC-LED-900	5.3	5.0	4 .61	4.0	3.2	2.9	2.3			
TLC-LED-1500	8.5	8.1	7.4	6.4	5.1	4.7	3.7			
Not teberreproduced in whole				ritt <u>en</u> o	onsent	o <u>f</u> lylu	sc <u>p</u> 5			
Sports Lighting, LLC. ©1981, 2 TLC-BT-575	3.4	1sco s 3.2	2.9 L	9111119 2.5	, 7 .8.	1.8	1.5			

EQUIPMENT LAYOUT

Attachment B – Revised Mitigation Monitoring and Reporting Plan

MITIGATION MONITORING AND REPORTING PROGRAM - MILLS HIGH SCHOOL ATHLETICS FIELDS PROJECT

When adopting a Mitigated Negative Declaration, the CEQA Guidelines [Section 15074(d)] require that Lead Agencies adopt a program for reporting on or monitoring the changes that it has required in the project or made a condition of approval to mitigate or avoid significant environmental effects.

This monitoring program for mitigation measures identified by the Mitigated Negative Declaration includes:

- 1. A list of mitigation measures with a space for the completion date,
- 2. The full text of the mitigation measures, and
- 3. Monitoring details, including: 1) agency responsible for implementation, 2) timing of implementation and monitoring, and 3) monitoring verification.

			MONITORING	VERIFICATION		
Identified Impact	Related Mitigation Measure	Implementation Entity	Monitoring and Verification Entity	Timing Requirements	Signature	Date

BIOLOGICAL RESOURCES					
Loss of active protected bird and bat	Measure BIO-1: Prevent Loss of Active	SMUHSD	SMUHSD	Condition of	
nests	Bird Nests. A pre-construction survey	Construction	Project	construction	
	for nesting birds shall be conducted by a	contractor	Manager/Consult	contract; field	
	qualified biologist within two weeks of		ing Biologist	verify	
	construction activities, if activities are to			implementation	
	occur within nesting/breeding season of			prior to start of	
	native bird species (February- August).			construction	
	If active nests are identified within 300				
	feet of construction, and would be				
	exposed to prolonged construction-				
	related noise above normal levels, a				
	buffer shall be implemented around nests				
	during the breeding season, or until a				
	biologist determines the young have				
	fledged. The size of the buffer and the				
	type of construction activity will depend				
	on multiple factors including relative				
	change in noise and disturbance during				
	construction activity, amount of				
	vegetative screening between activity				
	and nest, and sensitivity of species.				
	Measure BIO-2: Prevent Loss of				
	Roosting Habitat for Bat Species. The				
	potential of the large trees to provide				
	suitable roosting habitat shall be				
	assessed by a qualified bat biologist, and				
	if necessary, a roosting bat protection				
	plan shall be implemented. If bats are				
	determined to be using the site,				
	minimization measures shall include				
	prohibiting night work activities				
	(between 10pm and sunrise), and				
	minimizing work activities to outside of				

		MONITORING			VERIFICATION	
Identified Impact	Related Mitigation Measure	Implementation Entity	Monitoring and Verification Entity	Timing Requirements	Signature	Date

	the most sensitive breeding (non-volant)				
	period of April to August				
CULTURAL RESOURCES					
Potential impacts to archaeological deposits and human remains	Mitigation Measure CULT-1: Archaeological Deposits. If archaeological remains are encountered during project activities, project ground disturbances at the find and immediate vicinity shall be halted immediately until a qualified archaeologist can evaluate the finds (§15064.5 [f]). The archaeologist shall examine the finds and recommend mitigation measures which may include documentation in place, avoidance, testing, and/or data recovery. Project personnel should not collect cultural resources. Native American resources include chert or obsidian flakes, projectile points, mortars, and pestles; and dark friable soil containing shell and bone dietary debris, heat-affected rock, or human burials. Historic-period resources include stone or adobe foundations or walls; structures and remains with square nails; and refuse deposits or bottle dumps, often located in old wells or privies. Mitigation Measure CULT-2: Human Remains. California law recognizes the need to protect interred human remains,	SMUHSD Project Manager	SMUHSD Project Manager	Construction contractors shall monitor during ground disturbing activities; if cultural resources are encountered, archaeologist and NAHC, as applicable, shall determine appropriate treatment for the resources.	

			MONITORING		VERIFICAT	ΓION
Identified Impact	Related Mitigation Measure	Implementation Entity	Monitoring and Verification Entity	Timing Requirements	Signature	Date
	particularly Native American burials and					
	associated items of patrimony, from					
	vandalism and inadvertent destruction.					
	The procedures for the treatment of					
	discovered human remains are contained					
	in California Health and Safety Code					
	Section 7050.5 and Section 7052 and					
	California Public Resources Code Section					
	5097.					
	In accordance with the California Health					
	and Safety Code, if human remains are					
	uncovered during ground disturbing					
	activities all such activities in the vicinity					
	of the find shall be halted immediately					
	and the District or the District's					
	designated representative shall be notified.					
	The District shall immediately notify the					
	county coroner and a qualified					
	professional archaeologist. The coroner is					
	required to examine all discoveries of					
	human remains within 48 hours of					
	receiving notice of a discovery on private					
	or state lands (Health and Safety Code					1
	Section 7050.5[b]). If the coroner					
	determines that the remains are those of a					
	Native American, he or she must contact					
	the Native American Heritage					

		MONITORING			VERIFICATION	
Identified Impact	Related Mitigation Measure	Implementation Entity	Monitoring and Verification Entity	Timing Requirements	Signature	Date
	Commission (NAHC) by phone within 24					
	hours of making that determination					
	(Health and Safety Code Section 7050[c]).					
	The responsibilities of the District for					
	acting upon notification of a discovery of					
	Native American human remains are					
	identified in detail in the California Public					
	Resources Code Section 5097.9. The					
	District or their appointed representative					
	and the professional archaeologist will					
	consult with a Most Likely Descendent determined by the NAHC regarding the					
	removal or preservation and avoidance of					
	the remains and determine if additional					
	burials could be present in the vicinity.					
	build be present in the vienney.					
GEOLOGIC HAZARDS						
Geotechnical Hazards	<i>Mitigation Measure GEO-1.</i> The project's site clearing, site preparation, subgrade preparation and stabilization, fill, drainage, and any foundation systems shall be designed and constructed per the specifications set forth on the project geotechnical report.	SMUHSD Project Manager	SMUHSD/ Project geotechnical engineer	Prior to submittal of final design plans to Division of the State Architect		
Drainage, Erosion., Sedimentation	<i>Mitigation Measure GEO-2.</i> The project shall include a site drainage system to collect surface water and discharging it into an established storm drainage system.	SMUHSD Project Manager	SMUHSD/ Project civil engineer	Prior to submittal of final design plans to Division of the State Architect		

			MONITORING	VERIFICATION		
Identified Impact	Related Mitigation Measure	Implementation Entity	Monitoring and Verification Entity	Timing Requirements	Signature	Date

	The project Civil Engineer or Architect shall be responsible for designing the site drainage system and, an erosion control plan could be developed prior to construction per the current guidelines of the California Stormwater Quality Association's Best Management Practice Handbook.				
HYDROLOGY AND WATER QUALITY					
Impacts on Water Quality.	 Mitigation Measure HYD-1: Prior to the issuance of grading permits for the proposed Project, the Project engineers shall prepare a Stormwater Control Plan. The Stormwater Control Plan shall identify pollution prevention measures and practices to prevent polluted runoff from leaving the Project site. Mitigation Measure HYD-2: The District shall maintain in perpetuity the post-construction BMPs listed in the Stormwater Operations and Management Plan. The owner shall make changes or modifications to the BMPs to ensure peak performance. The owner shall be responsible for costs incurred in operating, maintaining, repairing, and replacing the BMPs. The owner shall conduct inspection and maintenance activities and complete annual reports. 	SMUHSD Project Manager	SMUHSD Project Manager/ Project Civil Engineer	Prior to submittal of final design plans to Division of the State Architect	

			MONITORING			ION
Identified Impact	Related Mitigation Measure	Implementation Entity	Monitoring and Verification Entity	Timing Requirements	Signature	Date

NOISE					
Construction Noise	Mitigation Measure NOISE-1: In order to minimize disruption and potential annoyance during construction, the following shall be implemented during construction: Construction activities for the project should be limited to the City's construction hours of Monday through Friday between 7:30 a.m. to 7:00 p.m., Saturday 8:00 a.m. to 6:00 p.m., and Sundays and holidays 9:00 a.m. to 6:00 p.m., unless otherwise authorized by the city. All construction equipment shall be equipped with mufflers and sound control devices (e.g., intake silencers and noise shrouds) that are in good condition and appropriate for the equipment. Maintain all construction equipment. Maintain all construction equipment shall be located on the site so as to maintain the greatest possible distance to the sensitive receptors. Unnecessary idling of internal 	SMUHSD Project Manager	Construction Manager	Include in construction contracts. Implement during construction.	

		MONITORING			VERIFICATION	
Identified Impact	Related Mitigation Measure	Implementation Entity	Monitoring and Verification Entity	Timing Requirements	Signature	Date
	 combustion engines should be strictly prohibited. Neighbors located adjacent to the construction site shall be notified of the construction schedule in writing. The construction contractor shall provide the name and telephone number an on-site construction liaison. In the event that construction noise is intrusive to the community, the construction liaison shall investigate the source of the noise and require that reasonable measures be implemented to correct the problem. 					
Baseball Field Public Address System Noise	<i>Mitigation Measure NOISE-2:</i> The new baseball PA system shall be designed and operated to not exceed a L_{max} of 58 dBA at locations LT-1 and ST-1. This will require distributing highly directional and carefully aimed loudspeakers around the bleachers and field. The distance between the loudspeakers and the coverage area shall be minimized to reduce spill to the community. In addition, the PA system output volume shall be regulated by an audio processor with the ability to limit the audio output levels (e.g. compressor/limiter).	SMUHSD Project Manager	SMUHSD Project Manager/ Acoustical Engineers	Design prior to installation of the PA system; Field verify and adjust after system installation, during testing.		

		MONITORING			VERIFICATION	
Identified Impact	Related Mitigation Measure	Implementation Entity	Monitoring and Verification Entity	Timing Requirements	Signature	Date