

IV. Environmental Impact Analysis

J.1 Public Services—Fire Protection

1. Introduction

This section of the Draft EIR evaluates whether new or physically altered fire facilities would be required to provide fire protection services to the Project, the construction of which could cause significant environmental impacts. The analysis includes a description of the existing fire protection services in the vicinity of the Project Site. The analysis uses the following metrics from the Los Angeles Fire Department (LAFD) to assess potential demands on fire protection services and whether increased demands would create the need for new or expanded facilities: fire flow requirements, emergency access, and the ability of the LAFD to provide adequate fire protection services based on current facilities, equipment, and staffing levels. This analysis is based, in part, on information available on the LAFD website; Inter-departmental correspondence from LAFD to the Department of City Planning (February 4, 2021), which is included in Appendix M of this Draft EIR; and the *District NoHo Utility Infrastructure Technical Report: Water, Wastewater, and Energy* (Utility Report), prepared by KPFF Consulting Engineers (January 2022), which is included in Appendix G of this Draft EIR.

2. Environmental Setting

a. Regulatory Framework

There are several plans, policies, and programs regarding Fire Protection at the federal, state, and local levels. Described below, these include:

- Occupational Safety and Health Administration
- Federal Emergency Management Act
- Disaster Mitigation Act of 2000
- California Building Code and California Fire Code
- California Fire Service and Rescue Emergency Aid System
- California Vehicle Code

- California Constitution Article XIII, Section 35
- California Governor's Office of Emergency Services
- City of Los Angeles Charter
- City of Los Angeles General Plan Safety Element
- Community Plan
- Los Angeles Municipal Code
- Propositions F and Q
- Measure J
- Los Angeles Fire Department Strategic Plan 2018–2020

(1) Federal

(a) Occupational Safety and Health Administration

The Federal Occupational Safety and Health Administrations (OSHA) as well as California OSHA (Cal-OSHA) enforce the provisions of the federal and state Occupational Safety and Health Acts, respectively, which collectively require safety and health regulations for construction under Part 1926 of Title 29 Code of Federal Regulations (CFR). The fire-related requirements of the Federal Occupational Safety and Health Act are specifically contained in Subpart F, Fire Protection and Prevention, of Part 1926. Examples of general requirements related to fire protection and prevention include maintaining fire suppression equipment specific to construction on-site; providing a temporary or permanent water supply of sufficient volume, duration, and pressure; properly operating the on-site fire-fighting equipment; and keeping storage sites free from accumulation of unnecessary combustible materials.

(b) Federal Emergency Management Act

The Federal Emergency Management Agency (FEMA) was established in 1979 via executive order and is an independent agency of the federal government. In March 2003, FEMA became part of the U.S. Department of Homeland Security with the mission to lead the effort in preparing the nation for all hazards and effectively manage federal response and recovery efforts following any national incident. FEMA also initiates proactive mitigation activities, trains first responders, and manages the National Flood Insurance Program and the U.S. Fire Administration.

(c) Disaster Mitigation Act of 2000

Disaster Mitigation Act (42 United States Code [USC] Section 5121) provides the legal basis for FEMA mitigation planning requirements for state, local, and Indian Tribal governments as a condition of mitigation grant assistance. It amends the Robert T. Stafford Disaster Relief Act of 1988 (42 USC Section 5121-5207) by repealing the previous mitigation planning provisions and replacing them with a new set of requirements that emphasize the need and creates incentives for state, tribal, and local agencies to closely coordinate mitigation planning and implementation efforts. This Act reinforces the importance of pre-disaster infrastructure mitigation planning to reduce disaster losses nationwide and the streamlining of the administration of federal disaster relief and programs to promote mitigation activities. Some of the major provisions of this Act include:

- Funding pre-disaster mitigation activities
- Developing experimental multi-hazard maps to better understand risk
- Establishing state and local government infrastructure mitigation planning requirements
- Defining how states can assume more responsibility in managing the Hazard Mitigation Grant Program (HMGP)
- Adjusting ways in which management costs for projects are funded

The mitigation planning provisions outlined in Section 322 of this Act establish performance-based standards for mitigation plans and require states to have a public assistance program (Advance Infrastructure Mitigation [AIM]) to develop county government plans. The consequence for counties that fail to develop an infrastructure mitigation plan is the chance of a reduced federal share of damage assistance from 75 percent to 25 percent if the damaged facility has been damaged on more than one occasion in the preceding 10-year period by the same type of event.

(2) State

(a) California Building Code and California Fire Code

The California Building Code (California Code of Regulations [CCR], Title 24, Part 2) is a compilation of building standards, including general fire safety standards for new buildings, which are presented with more detail in the California Fire Code (CCR Title 24, Part 9). California Building Code standards are based on building standards that have been adopted by state agencies without change from a national model code; building standards based on a national model code that have been changed to address particular California conditions; and building standards authorized by the California legislature but not

covered by the national model code. The 2019 edition of the California Building Code became effective on January 1, 2020.¹ The building standards in the California Building Code apply to all locations in California, except where more stringent standards have been adopted by state agencies and local governing bodies. Typical fire safety requirements of the California Fire Code include: the installation of fire sprinklers in all high-rise buildings; the establishment of fire resistance standards for fire doors, building materials, and particular types of construction; and the clearance of debris and vegetation within a prescribed distance from occupied structures within wildfire hazard areas. Specific California Fire Code fire safety regulations have been incorporated by reference in the Los Angeles Municipal Code (LAMC) with local amendments, as discussed below.²

(b) California Fire Service and Rescue Emergency Aid System

The LAFD participates in the California Fire Service and Rescue Emergency Mutual Aid System through which the California Governor's Office of Emergency Service (Cal OES), Fire and Rescue Division is responsible for the development, implementation and coordination of the California Fire Service and Rescue Emergency Mutual Aid Plan (Mutual Aid Plan).³ The Mutual Aid Plan outlines procedures for establishing mutual aid agreements at the local, operational, regional, and State levels, and divides the State into six mutual aid regions to facilitate the coordination of mutual aid. The LAFD is located in Region I. Through the Mutual Aid Plan, the OES is informed of conditions in each geographic and organizational area of the state, and the occurrence or imminent threat of disaster. All OES Mutual Aid Plan participants monitor a dedicated radio frequency for fire events that are beyond the capabilities of the responding fire department and provide aid in accordance with the management direction of the OES.⁴

(c) California Vehicle Code

Section 21806 of the California Vehicle Code (CVC) pertains to emergency vehicles responding to Code 3 incidents/calls.⁵ This section of the CVC states the following:

¹ *California Building Code (CCR, Title 24, Part 2).*

² *Los Angeles Fire Department, Mutual Aid Agreements/Disaster Declarations/Potential Fiscal Impacts, July 3, 2014.*

³ *Governor's Office of Emergency Services, Fire and Rescue Division, California Fire Service and Rescue Emergency Mutual Aid System, Mutual Aid Plan, revised.*

⁴ *Los Angeles Fire Department, Mutual Aid Agreements/Disaster Declarations/Potential Fiscal Impacts, July 3, 2014.*

⁵ *A Code 3 response to any emergency may be initiated when one or more of the following elements are present: a serious public hazard, an immediate pursuit, preservation of life, a serious crime in progress, and prevention of a serious crime. A Code 3 response involves the use of sirens and flashing red lights.*

Upon the immediate approach of an authorized emergency vehicle which is sounding a siren and which has at least one lighted lamp exhibiting red light that is visible, under normal atmospheric conditions, from a distance of 1,000 feet to the front of the vehicle, the surrounding traffic shall, except as otherwise directed by a traffic officer, do the following: (a) (1) Except as required under paragraph (2), the driver of every other vehicle shall yield the right-of-way and shall immediately drive to the right-hand edge or curb of the highway, clear of any intersection, and thereupon shall stop and remain stopped until the authorized emergency vehicle has passed. (2) A person driving a vehicle in an exclusive or preferential use lane shall exit that lane immediately upon determining that the exit can be accomplished with reasonable safety. (b) The operator of every street car shall immediately stop the street car, clear of any intersection, and remain stopped until the authorized emergency vehicle has passed. (c) All pedestrians upon the highway shall proceed to the nearest curb or place of safety and remain there until the authorized emergency vehicle has passed.

(d) California Constitution Article XIII, Section 35

Section 35 of Article XIII of the California Constitution at subdivision (a)(2) provides: “The protection of public safety is the first responsibility of local government and local officials have an obligation to give priority to the provision of adequate public safety services.” Section 35 of Article XIII of the California Constitution was adopted by the voters in 1993 under Proposition 172. Proposition 172 directs the proceeds of a 0.50-percent sales tax to be expended exclusively on local public safety services. California Government Code Sections 30051-30056 provide rules to implement Proposition 172. Public safety services include fire protection. Section 30056 mandates that cities are not allowed to spend less of their own financial resources on their combined public safety services in any given year compared to the 1992-93 fiscal year. Therefore, the City is required to use Proposition 172 to supplement its local funds used on fire protection services, as well as other public safety services. In *City of Hayward v. Trustee of California State University* (2015) 242 Cal. App. 4th 833, the court found under Section 35 that, cities have “a constitutional obligation to provide adequate fire protection services”.

(e) California Governor’s Office of Emergency Services

In 2009, the State of California passed legislation creating the California Governor’s Office of Emergency Services (Cal OES) and authorized it to prepare a Standard Emergency Management System (SEMS) program (Government Code Section 8607; Title 19 CCR Section 2401 et seq.), which sets forth measures by which a jurisdiction should handle emergency disasters. In California, SEMS provides the mechanism by which local government requests assistance. Non-compliance with SEMS could result in the state withholding disaster relief from the non-complying jurisdiction in the event of an emergency

disaster. Cal OES coordinates the state's preparation for, prevention of, and response to major disasters, such as fires, floods, earthquakes, and terrorist attacks. During an emergency, Cal OES serves as the lead state agency for emergency management in the state. It also serves as the lead agency for mobilizing the state's resources and obtaining federal resources. Cal OES coordinates the state response to major emergencies in support of local government. The primary responsibility for emergency management resides with local government. Local jurisdictions first use their own resources and, as they are exhausted, obtain more from neighboring cities and special districts, the county in which they are located, and other counties throughout the state through the statewide mutual aid system (see discussion of Mutual Aid Agreements, above). California Emergency Management Agency (Cal-EMA) maintains oversight of the state's mutual aid system.

(3) Local

(a) City of Los Angeles Charter

Section 520 of the Los Angeles City Charter states that the LAFD's duty is to control and extinguish injurious or dangerous fires and to remove that which is liable to cause those fires. It also requires the LAFD to enforce all ordinances and laws relating to the prevention or spread of fires, fire control, and fire hazards within the City, as well as to conduct fire investigations and protect lives and property in case of disaster or public calamity.

(b) City of Los Angeles Framework Element

The City of Los Angeles Framework Element (Framework Element), adopted in December 1996 and readopted in August 2001, sets forth general guidance regarding land use issues for the entire City of Los Angeles and defines citywide policies regarding land use, including infrastructure and public services. Goal 9J of the Infrastructure and Public Services Chapter of the Framework Element specifies that every neighborhood should have the necessary level of fire protection service, emergency medical service, and infrastructure.⁶ Objective 9.16 requires that the demand for existing and projected fire facilities and service be monitored and forecasted. Objective 9.17 requires that all areas of the City have the highest level of fire protection and emergency medical service, at the lowest possible cost, to meet existing and future demand. Objective 9.18 requires that the development of new fire facilities be phased with growth. Further, Objective 9.19 requires the maintenance of the LAFD's ability to assure public safety in emergency situations. Under the Framework Element, the City goal for response distance for emergency medical

⁶ *City of Los Angeles Framework Element, Chapter 9: Infrastructure and Public Services.*

response and the distance of fire stations for engine companies from neighborhood land uses is 1.5 miles.⁷ This is consistent with the specifications for response distances within the LAMC, discussed below. The relevant General Plan fire protection goals, objectives, and policies are included in Table IV.J.1-1 on page IV.J.1-8.

(c) City of Los Angeles General Plan Safety Element

The City of Los Angeles General Plan Safety Element (Safety Element), adopted on November 26, 1996, includes policies related to the City's response to hazards and natural disasters, including fires. In particular, the Safety Element sets forth requirements, procedures, and standards to facilitate effective fire suppression and emergency response capabilities. In addition, the City's Safety Element designates disaster routes. The nearest designated disaster routes to the Project Site are the Hollywood Freeway located approximately 1,750 feet to the west and Vineland Avenue located approximately 1,150 feet to the east.⁸ The relevant General Plan Safety Element emergency response (multi-hazard) goals, objectives, and policies are included in Table IV.J.1-2 on page IV.J.1-9.

(d) Community Plan

The Land Use Element of the City's General Plan includes 35 community plans. Community plans are intended to provide an official guide for future development and propose approximate locations and dimensions for land use. The community plans establish standards and criteria for the development of housing, commercial uses, and industrial uses, as well as circulation and service systems. The community plans implement the City's General Plan Framework at the local level and consist of both text and an accompanying generalized land use map. The community plans' texts express goals, objectives, policies, and programs to address growth in the community, including those that relate to fire protection required to support such growth. The community plans' maps depict the desired arrangement of land uses as well as street classifications and the locations and characteristics of public service facilities.

As discussed in Section IV.G, Land Use, of this Draft EIR, the Project is located within the North Hollywood–Valley Village Community Plan area.⁹ The North Hollywood–

⁷ *City of Los Angeles Framework Element, Chapter 9: Infrastructure and Public Services, Status of Infrastructure System/Facilities, Fire.*

⁸ *Los Angeles General Plan Safety Element, November 1996, Exhibit H, Critical Facilities & Lifeline Systems, p. 61.*

⁹ *The Los Angeles Department of City Planning is currently preparing the Southeast Valley Community Plan Update, which includes the North Hollywood–Valley Village Community Plan area (see <https://planning.lacity.org/plans-policies/community-plan-update/southeast-valley-community-plan-update>). As* (Footnote continued on next page)

Table IV.J.1-1
Relevant General Plan Fire Protection Goals, Objectives, and Policies—Framework Element:
Chapter 9, Infrastructure and Public Services

Goal 9J	Every neighborhood has the necessary level of fire protection service, emergency medical service (EMS) and infrastructure.
Objective 9.16	Monitor and forecast demand for existing and projected fire facilities and service.
Policy 9.16.1	Collect appropriate fire and population development statistics for the purpose of evaluating fire service needs based on existing and future conditions.
Objective 9.17	Assure that all areas of the City have the highest level of fire protection and EMS, at the lowest possible cost, to meet existing and future demand.
Policy 9.17.2	Identify areas of the City with deficient fire facilities and/or service and prioritize the order in which these areas should be upgraded based on established fire protection standards.
Policy 9.17.4	Consider the Fire Department's concerns and, where feasible adhere to them, regarding the quality of the area's fire protection and emergency medical services when developing General Plan amendments and zone changes, or considering discretionary land use permits.
Objective 9.19	Maintain the Los Angeles Fire Department's ability to assure public safety in emergency situations.
Policy 9.19.1	Maintain mutual aid or mutual assistance agreements with local fire departments to ensure an adequate response in the event of a major earthquake, wildfire, urban fire, fire in areas with substandard fire protection, or other fire emergencies.
Policy 9.19.3	Maintain the continued involvement of the Fire Department in the preparation of contingency plans for emergencies and disasters
<hr/> Source: City of Los Angeles 2001.	

Valley Village Community Plan, adopted on May 14, 1996, does not include any objectives or policies that specifically relate to fire protection.

(e) Los Angeles Municipal Code

The Los Angeles Fire Code (LAMC Chapter V, Article 7) incorporates by reference portions of the California Fire Code and the International Fire Code. The City's Fire Code sets forth regulatory requirements pertaining to the prevention of fires; the investigation of fires and life safety hazards; the elimination of fire and life safety hazards in any building or structure (including buildings under construction); the maintenance of fire protection equipment and systems; and the storage, use, and handling of hazardous materials. Specific regulations regarding fire prevention and protection are discussed below.

of February 2022, a draft of the revised community plan has not been released or adopted, and would be subject to revision following public comment. For purposes of this Draft EIR, the analysis is limited to the designations under the currently adopted Community Plan.

Table IV.J.1-2
Relevant Emergency Response (Multi-Hazard) Goals, Objectives, and Policies—Safety Element

Goal 2	A city that responds with the maximum feasible speed and efficiency to disaster events so as to minimize injury, loss of life, property damage and disruption of the social and economic life of the City and its immediate environs.
Objective 2.1	Develop and implement comprehensive emergency response plans and programs that are integrated with each other and with the City's comprehensive hazard mitigation and recovery plans and programs.
Policy 2.1.5	Response: Develop, implement, and continue to improve the City's ability to respond to emergency events. [All EOO emergency response programs and all hazard mitigation and disaster recovery programs related to protecting and reestablishing communications and other infrastructure, service and governmental operations systems implement this policy.]
Policy 2.1.6	<p>Standards/fire. Continue to maintain, enforce and upgrade requirements, procedures and standards to facilitate more effective fire suppression. [All peak load water and other standards, code requirements (including minimum road widths, access, and clearances around structures) and other requirements or procedures related to fire suppression implement this policy.]</p> <p>The Fire Department and/or appropriate City agencies shall revise regulations or procedures to include the establishment of minimum standards for location and expansion of fire facilities, based upon fire flow requirements, intensity and type of land use, life hazard, occupancy and degree of hazard so as to provide adequate fire and emergency medical event response. At a minimum, site selection criteria should include the following standards which were contained in the 1979 General Plan Fire Protection and Prevention Plan:</p> <p>Fire stations should be located along improved major or secondary highways. If, in a given service area, the only available site is on a local street, the site must be on a street which leads directly to an improved major or secondary highway.</p> <p>Fire station properties should be situated so as to provide drive-thru capability for heavy fire apparatus.</p> <p>If a fire station site is on the side of a street or highway where the flow of traffic is toward a signalized intersection, the site should be at least 200 feet from that intersection in order to avoid blockage during ingress and egress.</p> <p>The total number of companies which would be available for dispatch to first alarms would vary with the required fire flow and distance as follows: (a) less than 2,000 gpm would require not less than 2 engine companies and 1 truck company; (b) 2,000 but less than 4,500 gpm, not less than 2 or 3 engine companies and 1 or 2 truck companies; and (c) 4,500 or more gpm, not less than 3 engine companies and 2 truck companies.</p> <p>These provisions of the 1979 Plan were modified by the Fire Department for purposes of clarification.</p>
Goal 3	A city where private and public systems, services, activities, physical condition and environment are reestablished as quickly as feasible to a level equal to or better than that which existed prior to the disaster.
Objective 3.1	Develop and implement comprehensive disaster recovery plans which are integrated with each other and with the City's comprehensive hazard mitigation and emergency response plans and programs.

Table IV.J.1-2 (Continued)
Relevant Emergency Response (Multi-Hazard) Goals, Objectives, and Policies—Safety Element

Policy 3.1.1	Coordination: Coordinate with each other, with other jurisdictions and with appropriate private and public entities prior to a disaster and to the greatest extent feasible within the resources available, to plan and establish disaster recovery programs and procedures which will enable cooperative ventures, reduce potential conflicts, minimize duplication and maximize the available funds and resources to the greatest mutual benefit following a disaster. [All EOO recovery programs involving cooperative efforts between entities implement this policy.]
<hr/> <i>Source: City of Los Angeles 2001.</i>	

Section 57.106.5.2 provides that the Fire Chief shall have the authority to require drawings, plans, or sketches as may be necessary to identify: (1) occupancy access points; (2) devices and systems; (3) utility controls; (4) stairwells; and (5) hazardous materials/waste.

Section 57.107.6 requires that the installation, alteration, and major repair of the following be performed pursuant to a permit issued by the Department of Building and Safety: Fire Department communication systems, building communication systems, automatic elevators, heliports, emergency power systems, fire escapes, private fire hydrants, fire assemblies, fire protective signaling systems, pilot lights and warning lights for heat-producing equipment, refrigerant discharge systems, smoke detectors, emergency smoke control systems, automatic sprinkler systems, standpipe systems, and gas detection systems.

Section 57.118 establishes LAFD's fire/life safety plan review and LAFD's fire/life safety inspection for new construction projects.

Section 57.118.1.1 requires that all new high-rise buildings greater than 75 feet in height (measured from the lowest point with fire access) must include fire/life safety reviews by the Department of Building and Safety and LAFD.

Section 57.408 requires the preparation of an Emergency Plan that establishes dedicated personnel and emergency procedures to assist the LAFD during an emergency incident and establishes a drill procedure to prepare for emergency incidents. The Emergency Plan would also establish an on-site emergency assistance center and establish procedures to be followed during an emergency incident. The Emergency Plan must be submitted to the LAFD for approval prior to implementation and must be submitted annually (and revised if required by the LAFD).

Section 57.4704.4.3.1 of the LAMC requires that the Smoke detectors required by Chapter 9 of the LAMC (Building Code) be maintained in dependable operating condition and tested every six months or as required by the Fire Chief. An accurate record of such tests must be kept by the owner, manager, or person in charge of the property, and such records must be open to examination by the Fire Chief.

Section 57.4705.4 requires each building to have a rooftop emergency helicopter landing facility (EHLF) in a location approved by the Chief unless certain life safety features, as specified in LAFD Requirement No. 10, are provided and approved by the Fire Marshall in compliance with two options. Option 1 (EHLF Equivalency—HTLA) pertains to the provision of a Helicopter Tactical Landing Area (HTLA) in lieu of the emergency helicopter landing facility. An HTLA is defined by the LAFD as a “designated load bearing area with dimensions that will be less than those required for the load bearing area of an EHLF but with sufficient safety area around the HTLA to provide clearance for the helicopter.” LAFD Regulation No. 10 specifies HTLA and life safety feature requirements under different high-rise building height categories: over 75 feet, but less than 120 feet; over 120 feet, but less than 240 feet; over 240 feet, but less than 420 feet; and over 420 feet, but less than 1,000 feet. For Option 1, life safety features include:

- Two Fire Service Access Elevators
- Two-three stairways with roof access
- Enclosed elevator lobbies
- Escalator openings or stairways that are not part of the means of egress system and connect more than two stories shall be protected by approved power-operated automatic shutters at every penetrated floor

Option 2 (EHLF Equivalency—No EHLF and No HTLA) applies when all life safety elements included in Option 1 have been provided along with additional life safety features included in Option 2. For Option 2, the additional life safety features include:

- An automatic sprinkler system installed throughout the high-rise building. In light and ordinary hazard areas, other than parking garages, listed quick-response sprinklers, including extended coverage quick-response sprinklers, shall be used throughout the system. The National Fire Protection Agency (NFPA) 13 reduction to the hydraulic design area of operation for quick-response sprinkler systems shall not be permitted. Note: To meet the intent of this life safety feature it will typically require larger size branch lines for the automatic sprinkler system with quick response sprinkler heads.

- A Video Camera Surveillance System with cameras located in all Fire Service Access Elevator Lobbies and on every 5th floor landing in exit stairway shafts, with an additional camera at the top of the exit stairway shaft. LAFD video surveillance shall be usable from the LAFD's "fire control room" and installed with system cabling "survivability" requirements similar to NFPA Standard 72 for fire alarm systems. System cameras are required to be active during a fire alarm condition within the building.
- For high-rise buildings over 420 feet: egress stairways with a capacity, in inches, calculated by multiplying the occupant load served by a means of egress capacity factor of 0.3 inch per person. However, the capacity shall not be less than specified elsewhere in the building and fire codes.

Section 57.4705.1.6 requires at least one elevator in each bank of elevators to be available for fire emergency service and to have its controls designed so that key switches located in the building control station/fire command center will recall said elevator or elevators to the designated main floor. The elevator or elevators must be interconnected with the standby power.

Section 57.503.1.4 requires an approved, posted fire lane whenever any portion of an exterior wall is more than 150 feet from the edge of a roadway.

Section 57.507.3.1 establishes fire water flow standards, which vary from 2,000 gallons per minute (gpm) in low-density residential areas to 12,000 gpm in high-density commercial or industrial areas, with a minimum residual water pressure of 20 pounds per square inch (psi) remaining in the water system. Site-specific fire flow requirements are determined by the LAFD based on land use, life hazard, occupancy, and fire hazard level.

Section 57.507.3.2 addresses land use-based requirements for fire hydrant spacing and type. Regardless of land use, every first story of a residential, commercial, or industrial building must be within 300 feet of an approved hydrant. The site-specific number and location of hydrants would be determined as part of LAFD's fire/life safety plan review for each development.

Section 57.507.3.3 limits the maximum response distances to an LAFD station based on the type of land use. Applicable distances are based on LAFD's comment letter for each individual project.

LAMC Chapter V, Article 7, Section 57.512.1 provides that response distances, which are based on land use and fire flow requirements and range from 0.75 mile for an engine company to 2 miles for a truck company, shall comply with Section 57.507.3.3. Where a site's response distance is greater than permitted, all structures must have automatic fire sprinkler

systems. For projects with a required fire flow of 6,000 to 9,000 gpm like the Project, the required response distance is 1 mile for an engine company and 1.5 miles for a truck company.

(f) Propositions F and Q

Proposition F, the City of Los Angeles Fire Facilities Bond, was approved by voters in November 2000. This bond allocated \$532.6 million of general obligation bonds to finance the construction and rehabilitation of fire stations and animal shelters. Under Proposition F, new regional fire stations to provide training and other facilities at or near standard fire stations must be designed and built on a single site of at least 2 acres. This is to ensure that firefighters in training remain in the service area and are available to respond to emergency calls. Proposition F allocated \$378.6 million to build 19 new or replacement neighborhood Fire/Paramedic Stations and an Emergency Air Operations and Helicopter Maintenance Facility, for a total of 20 Proposition F projects. As of January 2017, all of the proposed projects have been completed.¹⁰

Proposition Q, the Citywide Public Safety Bond Measure, was approved by voters in March 2002. Proposition Q allocated \$600 million to renovate, improve, expand and construct public safety (police, fire, 911, and paramedic) facilities. In March 2011, the program was expanded to include renovations to existing LAFD facilities throughout the City. A total of 80 renovation projects at LAFD facilities were scheduled. These renovation projects include the installation of diesel exhaust capture systems, upgrades to air filtration and electrical systems, re-roofing, remodeling, parking lot repair, painting, and other improvements. The fire renovation projects identified under this measure have been completed.¹¹

(g) Measure J

Measure J, which was approved by voters at the November 7, 2006, General Election, is a charter amendment and ordinance that involves technical changes to Proposition F. Measure J allows new regional fire stations funded by Proposition F to be located in densely developed areas to be designed and built on one or more properties equaling less than two acres. Components of a regional fire station can be built on two or more sites within close proximity, or the facility can be designed to fit on a single site of less than two acres.

¹⁰ Los Angeles Fire Department, *Los Angeles 2000 Prop F Fire Facilities Bond, Progress Report Feb-March 2016*.

¹¹ City of Los Angeles, *Inter-Departmental Correspondence, SB 165 Annual Report Requirements for Fiscal Year 2012–2013 Proposition Q Program, June 30, 2016*.

(h) Los Angeles Fire Department Strategic Plan 2018–2020

The Los Angeles Fire Department Strategic Plan 2018–2020, A Safer City 2.0, is a collaborative effort between LAFD staff, city leaders, and community members to accomplish the LAFD's organizational vision. The Strategic Plan 2018–2020 builds upon the progress of the first Strategic Plan from 2015–2017, which resulted in the achievement of 70 percent of its goals. As provided in the Strategic Plan 2018–2020, five goals will guide the LAFD for the next three years: (1) Provide exceptional public safety and emergency service; (2) Embrace a healthy, safe and productive work environment; (3) Implement and capitalize on advanced technology; (4) Enhance LAFD sustainability and community resiliency; and (5) Increase opportunities for personal growth and professional development. As of February 2022, the Strategic Plan 2018–2020 is the most current available.

b. Existing Conditions

(1) Fire Protection Services, Facilities, and Response Times

LAFD serves as the City's life safety agency with approximately 3,435 uniformed fire personnel, providing fire prevention, firefighting, emergency medical care, technical rescue, hazardous materials mitigation, disaster response, public education, and community services.¹² There are 106 neighborhood fire stations strategically located across the LAFD's 469-square-mile jurisdiction.¹³ In addition, the LAFD is supported by 1,018 firefighters and 381 technical and administrative personnel.¹⁴

As shown in Figure IV.J.1-1 on page IV.J.1-15, there are two LAFD fire stations located within a 2-mile radius of the Project Site, and three outside the 2-mile radius.¹⁵ The closest station to the Project Site is Fire Station No. 60, which is the designated "first in" station, located approximately 0.4 mile southwest of the Project Site at 5320 Tujunga Avenue.¹⁶ As shown in Table IV.J.1-3 on page IV.J.1-16, Fire Station No. 60 consists of an engine, assessment light force (i.e. engine and truck company),¹⁷ paramedic

¹² LAFD, *Our Mission*, www.lafd.org/about/about-lafd/our-mission, accessed February 16, 2021.

¹³ LAFD, *Our Mission*, www.lafd.org/about/about-lafd/our-mission, accessed February 16, 2021.

¹⁴ LAFD, *Our Mission*, www.lafd.org/about/about-lafd/our-mission, accessed February 16, 2021.

¹⁵ Distances are provided by LAFD based on 11204 Cumpston Street. Source: Written correspondence from Kristin Crowley, Fire Marshal, Bureau of Fire Prevention and Public Safety, Los Angeles Fire Department, February 4, 2021.

¹⁶ Written correspondence from Kristin Crowley, Fire Marshal, Bureau of Fire Prevention and Public Safety, Los Angeles Fire Department, February 4, 2021.

¹⁷ A light force is a truck company with an engine, staffed by 6 firefighters. LAFD, *Apparatus*, www.lafd.org/about/about-lafd/apparatus, accessed August 31, 2021.



Figure IV.J.1-1
Fire Stations in the Vicinity of the Project Site

**Table IV.J.1-3
LAFD Fire Stations Located in the Project Vicinity**

Station No., Location, and Community Served	Distance from Project Site^a	Equipment	Staffing
Fire Station No. 60 5320 Tujunga Avenue North Hollywood, CA 91601	0.4 mile	<ul style="list-style-type: none"> • Engine and Truck • Assessment Light Force^b • Paramedic Rescue Ambulance • BLS Rescue Ambulance • Foam Tender 	16
Fire Station No. 86 4305 Vineland Avenue North Hollywood, CA 91602	1.7 miles	<ul style="list-style-type: none"> • Assessment Engine • Paramedic Rescue Ambulance • Swift Water Rescue Team • Brush Patrol 	6
Fire Station No. 102 13200 Burbank Boulevard Van Nuys, CA 91401	2.7 miles	<ul style="list-style-type: none"> • Assessment Engine • Paramedic Rescue Ambulance 	6
Fire Station No. 89 7063 Laurel Canyon Boulevard North Hollywood, CA 91605	2.8 miles	<ul style="list-style-type: none"> • Engine • Assessment Light Force^b • Paramedic Rescue Ambulance • BLS Rescue Ambulance • Urban Search and Rescue 	14
Fire Station No. 78 4041 Whitsett Avenue Studio City, CA 91604	3.5 miles	<ul style="list-style-type: none"> • Assessment Light Force^b • Paramedic Rescue Ambulance • EMS Battalion Captain • BLS Rescue Ambulance • Arson Investigation Unit 	13
<p>^a Distances are provided by LAFD based on 11204 Cumpston Street.</p> <p>^b A light force is a truck company with an engine, staffed by six firefighters. LAFD, Apparatus, www.lafd.org/about/about-lafd/apparatus, accessed August 31, 2021.</p> <p>Source: Written correspondence from Kristin Crowley, Fire Marshal, Bureau of Fire Prevention and Public Safety, Los Angeles Fire Department, February 4, 2021, and telephone conversation with Captain Miguel Meza of Fire Station No. 60, March 18, 2021.</p>			

rescue ambulance, BLS Rescue Ambulance and Foam Tender, and a staff of 16.¹⁸ Because Fire Station No. 60 is equipped with at least one engine and one truck company, it meets LAMC Chapter V, Article 7, Section 57.512.1 response distance requirements for the Project Site of 1 mile for an engine company and 2 miles for a truck company.

Secondary fire stations that serve the Project Site include Fire Station No. 86, located 1.7 miles south of the Project Site at 4305 Vineland Avenue; Fire Station No. 102,

¹⁸ Written correspondence from Kristin Crowley, Fire Marshal, Bureau of Fire Prevention and Public Safety, Los Angeles Fire Department, February 4, 2021.

located 2.7 miles west of the Project Site at 13200 Burbank Boulevard; and Fire Station No. 89, located 2.8 miles northwest of the Project Site at 7063 Laurel Canyon Boulevard; and Fire Station No. 78, located 3.5 miles southwest of the Project Site at 4041 Whitsett Avenue.¹⁹ Fire Station No. 86 consists of an assessment engine, paramedic rescue ambulance, swift water rescue team and brush control, and a staff of six; Fire Station No. 102 consists of an assessment engine and paramedic rescue ambulance, and a staff of six; Fire Station No. 89 consists of an engine, assessment light force, paramedic rescue ambulance, BLS rescue ambulance and urban search and rescue, and a staff of 14; and Fire Station No. 78 consists of an assessment light force, paramedic rescue ambulance, EMS Battalion Captain, BLS rescue ambulance and arson investigation unit, and a staff of 13.²⁰

The response times for January to December 2021 are shown in Table IV.J.1-4 on page IV.J.1-18. LAFD has not established response time standards for emergency response or adopted the National Fire Protection Association (NFPA) standard of 5 minutes for EMS response and 5 minutes, 20 seconds aid in emergency response.²¹ The City of Los Angeles has over 205 miles of major arterial routes that are equipped with FPS.²² According to the LAFD, although response time is considered in assessment of the adequacy of fire protection services, it is one factor among several that LAFD utilizes in evaluating its ability to respond to fires and life and health safety emergencies, along with a variety of other criteria, including required fire flow, response distance from existing fire stations, and the LAFD's judgment for fire protection and emergency services needs in an area. If the number of incidents in a given area increases, it is the LAFD's responsibility to assign new staff and equipment, as necessary, to maintain adequate levels of service. In conformance with the California Constitution Article XIII, Section 35(a)(2) and the *City of Hayward v. Board Trustee of California State University* (2015) 242 Cal, App. 4th 833, 847 ruling, the City is meeting its constitutional obligation to provide adequate public safety services.

(2) Emergency Access

Vehicular access to the Project Site and Off-Site Metro Parking Areas is currently provided by several local streets and avenues located to the north (Cumpston Street), west

¹⁹ Written correspondence from Kristin Crowley, Fire Marshal, Bureau of Fire Prevention and Public Safety, Los Angeles Fire Department, February 4, 2021.

²⁰ Written correspondence from Kristin Crowley, Fire Marshal, Bureau of Fire Prevention and Public Safety, Los Angeles Fire Department, February 4, 2021.

²¹ LADOT, Los Angeles Signal Synchronization Fact Sheet.

²² LAFD, Training Bulletin: Traffic Signal Preemption System for Emergency Vehicles, Bulletin No. 133, October 2008.

**Table IV.J.1-4
Average EMS and Non-EMS Response Times (2021)**

Station	Average Response Time to EMS Incident (Minutes:Seconds)	Average Response Time to Non-EMS Incident (Minutes:Seconds)
Fire Station No. 60	6:31	5:55
Fire Station No. 86	6:12	6:06
Fire Station No. 102	6:31	6:38
Fire Station No. 89	7:08	6:32
Fire Station No. 78	6:52	7:07
Citywide	6:55	6:33
<p>^a Response times are based on January–December 2021 data.</p> <p>Source: LAFD, FireStatLA, Station 60 Response Metrics for 2021 www.lafd.org/fsla/stations-map?station=60&year=2021, accessed February 15, 2022; LAFD, FireStatLA, Station 86 Response Metrics for 2021, www.lafd.org/fsla/stations-map?station=86&year=2021, accessed February 15, 2022; LAFD, FireStatLA, Station 102 Response Metrics for 2021, www.lafd.org/fsla/stations-map?station=102&year=2021, accessed February 15, 2022; FireStatLA, Station 89 Response Metrics for 2021, www.lafd.org/fsla/stations-map?station=89&year=2021, accessed February 15, 2022; FireStatLA, Station 78 Response Metrics for 2021, www.lafd.org/fsla/stations-map?station=78&year=2020, accessed February 15, 2022; and LAFD, FireStatLA, Citywide Response Metrics for 2021, www.lafd.org/fsla/stations-map?year=2021, accessed February 15, 2022.</p>		

(Tujunga Avenue), east (Fair Avenue), and south (Weddington Street), as well as Lankershim Boulevard and Chandler Boulevard which bisect the Project Site.²³ As indicated previously, the nearest designated disaster routes to the Project Site are the Hollywood Freeway located approximately 1,750 feet to the west and Vineland Avenue located approximately 1,150 feet to the east.²⁴

(3) Fire Water Infrastructure

As discussed in Section IV.M.1, Utilities and Service Systems—Water Supply and Infrastructure, of this Draft EIR, in addition to providing domestic water service, the Los Angeles Department of Water and Power (LADWP) also provides water for firefighting services in accordance with the City of Los Angeles Fire Code (LAMC Chapter V, Article 7). Domestic water service is available in the vicinity of the Project Site via LADWP water lines within the adjacent streets. According to the Utility Report, there are nine water mains in

²³ Driveways currently exist from all of these streets into the Project Site, with the exception of Lankershim Boulevard which provides substantial street frontage along but no driveways into the Project Site.

²⁴ Los Angeles General Plan Safety Element, November 1996, Exhibit H, Critical Facilities & Lifeline Systems, p. 61.

the Project Site vicinity, including: a 12-inch water main in Cumpston Street; an 8-inch water main in Fair Avenue; an 8-inch water main in South Chandler Boulevard; two water mains in Lankershim Boulevard (an 8-inch and a 12-inch line); a 36-inch water main in Tujunga Avenue; an 8-inch water main in Chandler Boulevard; a 4-inch water main in Bakman Street; and a 4-inch water main in Weddington Street. In addition, there is an existing water main within the vicinity of the proposed parking structure at the New East Lot, and a 12-inch water main within Vineland Avenue.²⁵

Also, according to the Utility Report, there are 13 fire connections to the Project Site. These connections appear to serve 13 public fire hydrants, including: two along Cumpston Street; three along Lankershim Boulevard; three along Chandler Boulevard; three along South Chandler Boulevard; one along Fair Avenue; and one along Vineland Avenue. The specific hydrant locations are identified below and shown in Figure 1 of the Utility Report:

- Eastern corner of Cumpston St. & Lankershim Blvd.
- Approximately 498 feet east from the east corner of Cumpston St. & Lankershim Blvd.
- Western corner of Cumpston St. & Fair Ave.
- Approximately 303 feet south from the corner of Cumpston St. & Fair Ave.
- Approximately 325 feet west from the corner of South Chandler Blvd. & Fair Ave.
- Approximately 230 feet from the northeast corner of South Chandler Blvd. & Lankershim Blvd.
- Western corner of Chandler Blvd. & Lankershim Blvd.
- Eastern corner of Chandler Blvd. & Tujunga Ave.
- Western corner of Chandler Blvd. & Tujunga Ave.
- Approximately 620 feet from the northeast corner of Chandler Blvd. & Tujunga Ave.
- Eastern corner of South Chandler Blvd. & Bakman St.
- Approximately 162 south of the corner of South Chandler Blvd. & Lankershim Blvd.

²⁵ KPFF Consulting Engineers, *District NoHo Utility Technical Report: Water, Wastewater, and Energy*, January 2022. Refer to Appendix G of this Draft EIR.

- Approximately 168 feet north of the corner South Chandler Blvd. & Vineland Ave.

In addition to the above public fire hydrants, additional public fire hydrants are located across the streets from the Project Site. See Figure 1 of the Utility Report for the locations of these hydrants.

(4) Fire Hazard Areas

There are no wildlands located adjacent to or in the vicinity of the Project Site. In addition, the Project Site is not located within a City-designated Very High Fire Hazard Severity Zone or Fire District No. 1.^{26,27}

3. Project Impacts

a. Thresholds of Significance

(1) State CEQA Guidelines Appendix G

In accordance with Appendix G of the CEQA Guidelines, a project would have a significant impact related to fire protection if it would:

Threshold (a): Result in substantial adverse physical impacts associated with the provision of new or physically altered government facilities (i.e., fire), need for new or physically altered governmental facilities, the construction of which would cause significant environmental impacts, in order to maintain acceptable service ratios, response times or other performance objectives for fire protection services.

For this analysis, the Appendix G threshold listed above is relied upon. The analysis utilizes factors and considerations identified in the *L.A. CEQA Thresholds Guide*, as appropriate to assist in answering the Appendix G thresholds. The *L.A. CEQA Thresholds Guide* states that the determination of significance shall be made on a case-by-case basis, considering the following factor to evaluate fire protection:

²⁶ City of Los Angeles, Department of City Planning, ZIMAS, <http://zimas.lacity.org/>, accessed February 17, 2021.

²⁷ Fire District No. 1 consists of areas identified by the City that are required to meet additional development regulations to mitigate fire hazard-related risks.

- A project would normally have a significant impact on fire protection if it requires the addition of a new fire station or the expansion, consolidation or relocation of an existing facility to maintain service.

b. Methodology

Project impacts regarding fire services are evaluated on a project-by-project basis. A project's land use, fire-related needs, and whether the project site meets the recommended response distance and fire safety requirements, as well as project design features that would reduce or increase the demand for fire protection services, are taken into consideration. Beyond the standards set forth in the Los Angeles Fire Code, consideration is given to the project size and components, required fire-flow, response distance for engine and truck companies, fire hydrant sizing and placement standards, access, and potential to use or store hazardous materials. The evaluation of impacts considers whether or not the development of the project would create the need for a new fire station or expansion, relocation, or consolidation of an existing facility to accommodate increased demand. Consultation with the LAFD is also conducted to determine the project's effect on fire protection services.

The need for or deficiency in adequate fire protection and emergency medical services in and of itself is not a CEQA impact, but rather a social and/or economic impact. Where a project causes a need for additional fire protection and emergency medical services resulting in the need to construct new facilities or additions to existing facilities, and the construction results in a potential impact to the environment, then the impact would need to be assessed in this Draft EIR. The ultimate determination of whether there is a significant impact to the environment related to fire protection and emergency medical services from a project is determined by whether construction of new or expanded fire protection and emergency medical facilities is a reasonably foreseeable direct or indirect effect of the project. There are no current capital improvement plans for the construction or expansion of fire facilities in the impact area. Therefore, the City makes the following assumptions based on existing zoning standards and based on historical development of fire and emergency facilities, that in the event the City determines that expanded or new emergency facilities are warranted, such facilities: (1) would occur where allowed under the designated land use; (2) would be located on parcels that are infill opportunities on lots that are between 0.5 and 1 acre in size; and (3) could qualify for a categorical exemption under CEQA Guidelines Section 15301 or 15332 or Mitigated Negative Declaration.

c. Project Design Features

No Project Design Features are proposed with respect to fire protection. However, as discussed in Section IV.K, Transportation, of this Draft EIR, pursuant to Project Design Feature TR-PDF-1 the Applicant would implement a Construction Traffic Management Plan

that would include provisions for maintaining emergency access to the Project Site during construction.

d. Analysis of Project Impacts

Threshold (a): Would the Project result in substantial adverse physical impacts associated with the provision of new or physically altered government facilities (i.e., fire), need for new or physically altered governmental facilities, the construction of which would cause significant environmental impacts, in order to maintain acceptable service ratios, response times or other performance objectives for fire protection services?

(1) Impact Analysis

(a) Construction

Construction activities have the potential to result in accidental on-site fires by exposing combustible materials (e.g., wood, plastics, sawdust, coverings and coatings) to fire risks from machinery and equipment sparks, and from exposed electrical lines, chemical reactions in combustible materials and coatings, and lighted cigarettes. In most cases, implementation of good housekeeping procedures by the construction contractors and work crews would minimize these hazards. Construction activities also have the potential to affect fire protection services by adding construction traffic to the street network and by necessitating partial lane closures during street improvements and utility installations. These impacts would be less than significant for the following reasons:

- Construction impacts are inherently temporary in nature and do not cause lasting effects that would impact LAFD fire protection services.
- In accordance with OSHA regulations set forth in 29 CFR, Part No. 1926, construction managers and personnel would be trained in emergency response and fire safety operations and fire suppression equipment (e.g., fire extinguishers) specific to construction would be maintained on-site, reducing fire risk on-site.
- Partial lane closures would not significantly affect emergency vehicles, the drivers of which normally have a variety of options for dealing with traffic pursuant to CVC Section 21806, such as using their sirens to clear a path of travel or driving in the lanes of opposing traffic.
- Impacts that could temporarily affect emergency response are addressed through the Construction Traffic Management Plan, prepared for the Project pursuant to Project Design Feature TR-PDF-1 in Section IV.K, Transportation, of this Draft EIR. Project Design Feature TR-PDF-1 would ensure that adequate

and safe access remains available within and near the Project Site during construction activities. The Project would also employ temporary traffic controls, such as flag persons to control traffic movement during temporary traffic flow disruptions. Traffic management personnel would be trained to assist in emergency response by restricting or controlling the movement of traffic that could interfere with emergency vehicle access. Appropriate construction traffic control measures (e.g., detour signage, delineators, etc.) would also be implemented, as necessary, to ensure emergency access to the Project Site and traffic flow is maintained on adjacent rights-of-way.

- The Project would not affect any designated disaster routes - the nearest such routes to the Project Site are the Hollywood Freeway located approximately 1,750 feet to the west and Vineland Avenue located approximately 1,150 feet to the east.²⁸

Based on the above, Project construction would not affect fire protection services to the extent that new or physically altered fire facilities would be needed in order to maintain acceptable service ratios, response distances, or other performance objectives for fire protection services. Therefore, construction-related impacts on fire protection would be less than significant.

(b) Operation

(i) Facilities and Equipment

The Project Site would continue to be served by Fire Station No. 60, the “first-in” station for the Project Site, located approximately 0.4 mile southwest of the Project Site. As shown in Table IV.J.1-3 on page IV.J.1-16, Fire Station No. 60 is equipped with an engine, truck, assessment light force (i.e., engine and truck company together staffed by six firefighters), paramedic rescue ambulance, BLS rescue ambulance and foam tender, and a staff of 16. In addition, Fire Station No. 86, located 1.7 miles south of the Project Site, is equipped with an assessment engine, paramedic rescue ambulance, swift water rescue team and brush patrol, and staff of six. As such, the existing fire protection facilities meet LAFD’s fire flow based response distance requirements for the Project of 1 mile for an engine company and 1.5 miles for a truck company based on the Project’s required fire flow of 6,000 to 9,000 GPM.²⁹ Furthermore, as shown in Table IV.J.1-3, although located beyond the specified response distance requirements, Fire Station Nos. 102, 89, and 78 have been identified by the LAFD as capable of initial responses needed at the Project

²⁸ *Los Angeles General Plan Safety Element, November 1996, Exhibit H, Critical Facilities & Lifeline Systems, p. 61.*

²⁹ *Written correspondence from Kristin Crowley, Fire Marshal, Bureau of Fire Prevention and Public Safety, Los Angeles Fire Department, February 4, 2021. Included as Appendix M of this Draft EIR.*

Site. Lastly, LAFD has concluded that, based on the response distance criteria, fire protection would be considered adequate to serve the Project.³⁰

The Project's development of 1,527 dwelling units would introduce a new residential population of an estimated 3,717 persons, based on the most recent persons per unit factors from LADOT's VMT Calculator.³¹ In addition, the Project would include up to 105,125 square feet of commercial uses, including retail and restaurant spaces, along with up to 580,374 square feet of office uses.³² Based on employee generation rates provided by LADOT and DCP, conservatively assuming 100 percent of the restaurant uses would be fast food (identified by the LADOT as a higher employee generation rate), the proposed commercial and office uses would result in approximately 2,882 employees.^{33,34} When accounting for the industrial/warehouse uses to be removed from the Project Site and Off-Site Metro Parking Areas, the Project would result in a net increase of 2,821 employees.^{35,36} Therefore, the Project's population would increase the demand for LAFD fire protection services, which could, in turn, result in a need for new or physically altered government facilities.

³⁰ Written correspondence from Kristin Crowley, Fire Marshal, Bureau of Fire Prevention and Public Safety, Los Angeles Fire Department, February 4, 2021. Included as Appendix M of this Draft EIR.

³¹ Based on population generation factors by use type from the Los Angeles Department of Transportation and Los Angeles Department of City Planning, City of Los Angeles VMT Calculator Documentation Version 1.3, May 2020, Table 1. They are in residents per residential unit, and include: Multi-Family Residential = 2.25 and Affordable Housing-Family = 3.14: $(1,216 * 2.25) + (311 * 3.14) = 3,713$. However, because the VMT calculator itself uses 2.2533455879541 residents per multifamily unit, the resulting population is 3,717 $(1,216 * 2.2533455879541) + (311 * 3.14) = 3,717$.

³² As discussed in Section II, Project Description, of this Draft EIR, the Project includes a potential land use exchange of up to 75,000 square feet of retail/restaurant uses for up to 75,000 square feet of office space should future market conditions warrant. Under this scenario, the Project would generate a net increase of 2,731 employees.

³³ Los Angeles Department of Transportation and Los Angeles Department of City Planning, City of Los Angeles VMT Calculator Documentation Version 1.3, May 2020, Table 1. Based on 2.0 employees/ksf for general retail uses; 6.7 employees/ksf for fast food restaurant; and 4.0 employees/ksf for general office uses: $(28.4 * 2.0) + (75.0 * 6.7) + (580.374 * 4.0) = \sim 2,882$ employees.

³⁴ Includes the 1,725 square foot Lankershim Depot to remain.

³⁵ On December 21, 2020, a fire destroyed the existing building on Block 7. Nevertheless, because it was present at the time the NOP was published on July 7, 2020, it is considered part of the existing conditions.

³⁶ Los Angeles Department of Transportation and Los Angeles Department of City Planning, City of Los Angeles VMT Calculator Documentation Version 1.3, May 2020, Table 1. Based on 1.0 employee/thousand square feet (ksf) for warehouse uses and 6.7 employees/ksf for fast food restaurant: $(23.420 * 1.0) + (1.725 * 6.7) + (25.691 * 1.0) = \sim 61$ existing employees. $2,882$ proposed employees – 61 existing employees = $2,821$ net new employees.

However, the Project would implement Los Angeles Building and Fire Code requirements, including, but not limited to, structural design, building materials, site access, clearances, hydrants, fire flow, storage and management of hazardous materials, alarm and communications systems, and building sprinkler systems. Compliance with applicable City Building Code and Fire Code requirements would be demonstrated as part of LAFD's fire/life safety plan review and LAFD's fire/life safety inspection for new construction projects, as set forth in LAMC Section 57.118, prior to the issuance of a building permit. The Project would provide all applicable life safety features, including automatic fire sprinklers, a video camera surveillance system, egress stairways, fire service access elevators, stairways with roof access, enclosed elevator lobbies, escalator openings, or stairways, etc., as set forth in the written correspondence from the LAFD included in Appendix M of this Draft EIR.

The Project also includes high rise buildings.³⁷ As a result, LAMC Section 57.4705.4 requires: (1) an emergency helicopter landing facility on the roof of each high rise building; or (2) the implementation of one of two alternate options. Here, the high rise buildings propose to comply with Option 2 of LAFD Requirement No. 10, with approval from the Fire Marshall. In compliance with Option 2, the Project would include all applicable additional life safety features, including automatic fire sprinklers, a video camera surveillance system, egress stairways, fire service access elevators, stairways with roof access, enclosed elevator lobbies, and escalator openings or stairways. As indicated above, the Project would also implement all applicable Los Angeles Building Code, Fire Code, and LAFD requirements. Compliance with applicable City Building Code and Fire Code requirements would be confirmed as part of LAFD's fire/life safety plan review and fire/life safety inspection for new construction projects, which requirements are set forth in LAMC Section 57.118 and must be satisfied prior to the issuance of a building permit.

Compliance with applicable regulatory requirements, including LAFD's fire/life safety plan review and LAFD's fire/life safety inspection for new construction projects, would ensure that adequate fire prevention features would be provided that would substantially reduce the demand on LAFD facilities and equipment resulting from the Project. As such, compliance with Fire Code requirements would minimize the potential for incidents requiring an emergency response by LAFD and therefore reduce the need for a new fire station, or the expansion, consolidation, or relocation of an existing fire station.

³⁷ LAMC Section 57.118.1.1 defines a high-rise building as a building for human occupancy of 75 feet or higher, as measured from the first occupied floor or occupied roof elevation above the lowest level of Fire Department vehicle access. The District NoHo Project would include buildings of up to 322 feet in height, with Project Site Blocks 1, 2, 3, 4, 5 and 8 to include buildings of 75 feet in height or greater.

Lastly, based on the analysis and the constitutional requirement stated in the California Constitution Article XIII, Section 35(a)(2) to provide these services, and the *Hayward* ruling, it is reasonable to conclude that: (1) Project operation would not require the addition of a new fire station or the expansion, consolidation, or relocation of an existing facility in order to maintain service; (2) such services will be provided by a local jurisdiction; and (3) the Project would not inhibit LAFD emergency response. Also, as indicated previously, the City makes the following assumptions based on existing zoning standards and based on historical development of fire and emergency facilities, that in the event the City determines that expanded or new emergency facilities are warranted, such facilities: (1) would occur where allowed under the designated land use, (2) would be located on parcels that are infill opportunities on lots that are between 0.5 and 1 acre in size, and (3) could qualify for a categorical exemption under CEQA Guidelines Section 15301 or 15332 or Mitigated Negative Declaration. Finally, as indicated previously, LAFD has concluded that, based on the response distance criteria, fire protection would be considered adequate to serve the Project.³⁸

Based on the above, no new or expanded fire station would be required to serve the Project.

(ii) Emergency Access

Operation of the Project would not include the installation of barriers (e.g., perimeter fencing, fixed bollards, etc.) that could impede emergency vehicle access within and in the vicinity of the Project Site. The Project does, however, include construction of three internal private streets, including the shared street District Way and extensions of Elmer Avenue and Klump Avenue. These streets would be designed to meet all applicable City Building Code and Fire Code requirements regarding site access, including providing adequate emergency vehicle access. Compliance with applicable City Building Code and Fire Code requirements, including emergency vehicle access, would be confirmed as part of LAFD's fire/life safety plan review and LAFD's fire/life safety inspection for new construction projects, as set forth in LAMC Section 57.118, and which are required prior to the issuance of a building permit.

Furthermore, the area surrounding the Project Site includes an established street system, consisting of freeways, primary and secondary arterials, and collector and local streets, which provide regional, sub-regional, and local access and circulation within the Project's traffic study area. Based on the Project Site's location within a highly urbanized area of the City, the streets surrounding the Project Site were designed as standard streets

³⁸ Written correspondence from Kristin Crowley, Fire Marshal, Bureau of Fire Prevention and Public Safety, Los Angeles Fire Department, February 4, 2021. Included as Appendix M of this Draft EIR.

in terms of pavement width and thickness, curb and gutter, and horizontal and vertical curvature. Therefore, the street system surrounding the Project Site is not considered substandard. Additionally, drivers of emergency vehicles have a variety of options for avoiding traffic, such as using sirens and flashing lights to clear a path of travel, pursuant to CVC Section 21806. As such, emergency access to the Project Site and surrounding uses would be maintained at all times, and the increase in traffic generated by the Project would not significantly impact emergency vehicle response to the Project Site and surrounding uses, including along City-designated disaster routes. Furthermore, the Project's driveway and internal circulation would be designed to incorporate all applicable City Building Code and Fire Code requirements regarding site access, including providing adequate emergency vehicle access.

Compliance with applicable City Building Code and Fire Code requirements, including emergency vehicle access, would be demonstrated as part of: (1) the initial review of the conceptual site plans by the applicable City departments (i.e., Engineering, LAFD, etc.) and the identification by these departments of required Conditions of Approval for the Project; (2) site plan review by the applicable City departments; (3) LAFD fire/life safety plan review; and (4) LAFD fire/life safety inspection for new construction projects, as set forth in LAMC Section 57.118. The first of these reviews would be conducted as part of the current CEQA process, the second and third of these reviews prior to the issuance of building permits, and the fourth of these reviews prior to the issuance of certificates of occupancy.

(iii) Fire Flow

As described in Section IV.M.1, Utilities and Service Systems—Water Supply, of this Draft EIR, domestic and fire water service to the Project Site would continue to be supplied by LADWP. Fire flow to the Project would be required to meet City fire flow requirements. As previously discussed, LAMC Section 57.507.3.1 establishes fire flow standards by development type. In its service letter dated February 4, 2021, included as Appendix M of this Draft EIR, LAFD set the required fire flow for this Project at 6,000 to 9,000 gpm from four to six fire hydrants flowing simultaneously, with a residual water pressure of 20 gpm.

As discussed in the Utility Report, included as Appendix G of this Draft EIR, the Information of Fire Flow Availability Report (IFFAR) submitted to LADWP shows 11 nearby hydrants flowing simultaneously for a combined 16,500 gpm.³⁹ Therefore, as shown by the

³⁹ Because LAFD considers the entire Project (Blocks 0-8) to be one block, the 16,500 gpm requirement will be sufficient for the entire Project based on LAMC requirements.

IFFAR, the Project would have adequate fire flow available to demonstrate compliance with LAMC Section 57.507.3.⁴⁰

In addition, the Project would incorporate fire sprinkler suppression system in all the proposed buildings.⁴¹ It should be noted that the proposed ancillary parking structures will be fully sprinklered and thus new hydrants are not proposed in the immediate vicinity of these structures. Per LAMC 94.2020.0, which adopts by reference NFPA 14-2013, including Section 7.10.1.1.5, the maximum allowable fire sprinkler demand for a fully or partially sprinklered building is 1,250 gpm. Because the Service Advisory Request submitted to LADWP confirms there is sufficient pressure to serve the Project, adequate water pressure is available to operate the proposed fire sprinkler suppression system. Furthermore, the incorporation of the proposed fire sprinkler suppression system in all the proposed buildings would allow for a reduction or elimination of the Project's public hydrant demand.⁴² Specifically, Section B105.3 of the California Fire Code states that for buildings equipped with an approved automatic sprinkler system, the water supply shall be capable of providing the greater of the required automatic sprinkler system demand or the hydrant fire flow demand. Despite Section B105.3, the Project would meet both the fire hydrant fire flow demand and the automatic sprinkler system demand for the Project as indicated above.

(iv) Conclusion

Based on the analysis and the constitutional requirement stated in the California Constitution Article XIII, Section 35(a)(2) to provide these services, and the *Hayward* ruling, it is reasonable to conclude that: (1) Project operation would not require the addition of a new fire station or the expansion, consolidation, or relocation of an existing facility in order to maintain service; (2) such services will be provided by a local jurisdiction; and (3) the Project would not inhibit LAFD emergency response. Because of this, and based on the above analysis, the Project is not anticipated to generate a demand for additional fire facilities. Project operation would not result in substantial adverse physical impacts associated with the provision of new or physically altered government facilities, need for new or physically altered governmental facilities, the construction of which would cause significant environmental impacts, in order to maintain acceptable service ratios,

⁴⁰ KPFF Consulting Engineers, *District NoHo Utility Technical Report: Water, Wastewater, and Energy*, January 2022. Refer to Appendix G of this Draft EIR.

⁴¹ KPFF Consulting Engineers, *District NoHo Utility Technical Report: Water, Wastewater, and Energy*, January 2022. Refer to Appendix G of this Draft EIR.

⁴² KPFF Consulting Engineers, *District NoHo Utility Technical Report: Water, Wastewater, and Energy*, January 2022. Refer to Appendix G of this Draft EIR.

response times, or other performance objectives for fire protection services. Therefore, impacts to fire protection during Project operation would be less than significant, and no mitigation measures are required.

(2) Mitigation Measures

Project-level impacts with regard to fire protection facilities would be less than significant. Therefore, no mitigation measures are required.

(3) Level of Significance After Mitigation

Impacts were determined to be less than significant without mitigation. Therefore, no mitigation measures were required, and the impact level remains less than significant.

e. Cumulative Impacts

(1) Impact Analysis

The geographic context for the cumulative impact analysis for fire protection are the service areas of Fire Station Nos. 60, 86, 102, 89, and 78. The Project, in conjunction with growth forecasted in the City through 2037 (i.e., the Project buildout year), would cumulatively generate a demand for fire protection service, thus potentially resulting in cumulative impacts on fire protection facilities. Cumulative growth in the greater Project area through 2037 includes specific known development projects, growth that may be projected as a result of the land use designation and policy changes contained in the North Hollywood–Valley Village Community Plan Update,⁴³ as well as general ambient growth projected to occur.

As discussed in Section III, Environmental Setting, of this Draft EIR, the projected growth reflected by Related Project Nos. 1 through 34 is a conservative assumption, as some of the related projects may not be built out by 2037 (i.e., the Project buildout year), may never be built, or may be approved and built at reduced densities. To provide a conservative forecast, the future baseline forecast assumes that Related Project Nos. 1 through 34 are fully built out by 2037, unless otherwise noted.

⁴³ The Los Angeles Department of City Planning is currently preparing the Southeast Valley Community Plan Update, which includes the North Hollywood–Valley Village Community Plan area (see <https://planning.lacity.org/plans-policies/community-plan-update/southeast-valley-community-plan-update>). As of February 2022, a draft of the revised community plan has not been released or adopted, and would be subject to revision following public comment. For purposes of this Draft EIR, the analysis is limited to the designations under the currently adopted Community Plan.

It is conservatively assumed that all of the identified related projects and ambient growth projections fall within the service areas of Fire Station Nos. 60, 86, 102, 89, and 78. The increase in development and residential service populations from the Project, related projects, as well as other future development in the North Hollywood–Valley Village Community Plan area would result in a cumulative increase in the demand for LAFD services and could have a cumulative impact on fire services resulting in a need for new or physically altered government facilities. However, based on the analysis and the constitutional requirement stated in the California Constitution Article XIII, Section 35(a)(2) to provide these services, and the *Hayward* ruling, it is reasonable to conclude that: (1) Project and related project operation would not require the addition of a new fire station or the expansion, consolidation, or relocation of an existing facility in order to maintain service; (2) such services will be provided by a local jurisdiction; and (3) the Project and related projects would not inhibit LAFD emergency response. Also, as indicated previously, the City makes the following assumptions based on existing zoning standards and based on historical development of fire and emergency facilities, that in the event the City determines that expanded or new emergency facilities are warranted, such facilities: (1) would occur where allowed under the designated land use; (2) would be located on parcels that are infill opportunities on lots that are between 0.5 and 1 acre in size; and (3) could qualify for a categorical exemption under CEQA Guidelines Section 15301 or 15332 or Mitigated Negative Declaration. Finally, as indicated previously, LAFD has concluded that, based on the response distance criteria, fire protection would be considered adequate to serve the Project.⁴⁴ Therefore, even if a new or expanded fire station was required to serve cumulative development: (1) the construction of an expanded or new fire station would not result in significant effects on the environment; and (2) the Project's contribution to the need for such expanded or new fire station would not be cumulatively considerable.

Also, similar to the Project, the related projects and other future development projects in the Community Plan area would be reviewed by the LAFD to ensure that sufficient fire safety and hazards measures are implemented. Furthermore, each related project and other future development projects in the Community Plan area would be required to comply with regulatory requirements related to fire protection services. In addition, the Project, related projects, and other future development projects in the Community Plan area would be subject to the City's standard construction permitting process, which includes a review by LAFD for compliance with building and site design standards related to fire/life safety, as well as coordinating with LADWP to ensure that local fire flow infrastructure meets current code standards for the type and intensity of land uses involved. Furthermore, given that the Project Site is located within an urban area, each of

⁴⁴ Written correspondence from Kristin Crowley, Fire Marshal, Bureau of Fire Prevention and Public Safety, Los Angeles Fire Department, February 4, 2021. Included as Appendix M of this Draft EIR.

the related projects identified in the area, as well as other future developments, would likewise be developed within urbanized locations that fall within an acceptable distance from one or more existing fire stations. The Project would also generate revenues to the City's General Fund (in the form of property taxes, sales revenue, etc.) that could be applied toward the provision of new fire station facilities and related staffing, as deemed appropriate.⁴⁵

Based on the analysis and the constitutional requirement stated in the California Constitution Article XIII, Section 35(a)(2) to provide these services, it is reasonable to conclude that Project and related project operation would not require the addition of a new fire station or the expansion, consolidation, or relocation of an existing facility in order to maintain service; such services will be provided by a local jurisdiction; and would not inhibit LAFD emergency response. Also, through the City's regular budgeting efforts, LAFD's resource needs, including staffing, equipment, trucks and engines, ambulances, other special apparatuses and possibly station expansions or new station construction, would be identified and allocated according to the priorities at the time. LAFD has no known or proposed plans to expand fire facilities or construct new facilities in the area either because of this Project or other projects in the service area. However, if LAFD determines that new facilities are necessary at some point in the future, such facilities: (1) would occur where allowed under the designated land use; (2) would likely be located on parcels that are infill opportunities on lots that are between 0.5 and 1 acre in size; and (3) could qualify for a categorical exemption under CEQA Guidelines Section 15301 or 15332 or a Mitigated Negative Declaration and would not be expected to result in significant impacts.⁴⁶ Further analysis, including a specific location, would be speculative and beyond the scope of this document. As such, cumulative impacts on fire protection services would be less than significant.

Based on the above, a cumulatively considerable increase in fire protection services demand that would require a new fire station, or the expansion of an existing fire station, the construction of which could cause significant environmental impacts, is not anticipated from the development of the Project together with the related projects, and cumulative impacts related to fire protection services would be less than significant.

⁴⁵ City of Los Angeles, *Proposed Budget for the Fiscal Year 2018–19*.

⁴⁶ Although an EIR was prepared for the construction of LAFD Fire Station No. 39, the EIR concluded there would be no significant impacts. See *Notice of Determination for Van Nuys Fire Station 39*.

(2) Mitigation Measures

Cumulative impacts with regard to fire protection facilities would be less than significant. Therefore, no mitigation measures are required.

(3) Level of Significance After Mitigation

Cumulative impacts related to fire protection facilities would be less than significant without mitigation. Therefore, no mitigation measures were required, and the impact level remains less than significant.