			NOTICE OF	EXEMPTION	2020090141
TO:	Office of Planning and 1400 – 10 <sup>th</sup> Street, Ro Sacramento, CA 9581	om 212	FROM:	Office of Facility Pla	ent of Corrections and Rehabilitation anning, Construction and Management e Road, Suite B, Sacramento, CA 95827
PROJECT TITLE: Chlorine Injection System Installation					
PROJECT LOCATION(S): California Health Care Facility, 7707 Austin Road, Stockton CA, 95215					
Description Of Nature, Purpose, And Beneficiaries Of Project: The purpose of the California Health Care Facility (CHCF) Chlorine Injection System Installation project is for California Department of Corrections and Rehabilitation to design and construct a chlorine injection system to increase potable water residual chlorine levels before entering the potable water distribution system at CHCF and Northern California Youth Correctional Center (NCYCC). The project scope includes construction of an above ground 120-gallon chemical storage tank, chemical injection system for sodium hypochlorite, a chlorine analyzer, and flow meter. The project also includes installation of a 48 square foot prefabricated metal cabinet to house the chemical storage tank and electronic control equipment on an existing concrete pad adjacent to the existing potable water booster pumps. The chlorine injection system will ensure compliance with the Environmental Protection Agency and State Water Resources Control Board drinking water quality standards related to chlorine levels at CHCF and NCYCC.  All work shall be in compliance with CDCR Design and Construction Policy Guidelines, Building Codes and State Fire Marshal requirements.					
Name Of Public Agency Approving Project: California Department of Corrections and Rehabilitation					
	Person Or Agency Out Project:				ehabilitation, Office of Facility Planning, Placerville Road, Sacramento, CA 95827
EXEMPT STATUS:  Ministerial (Sec. 21080(b)(1); 15268)  Declared Emergency (Sec. 21080(b)(3); 15269(a))  Emergency Project (Sec. 21080(b)(4); 15269(b)(c))  Categorical Exemption Class 1, CEQA Guidelines Section 15301 (Existing Facilities)					
Reason Why Project Is Exempt: The project is categorically exempt from CEQA under the "Class 1" (14 CCR §15301) exemption per the CEQA Guidelines because the project involves negligible or no expansion of an existing use and therefore exempt from the requirement for preparing an environmental document.					
Contact Person: Telephone No.:  Peter J Connelly, Jr, Environmental Planner, 916-255-3010					
Date Red	ceived For Filing:			of last	20 266
Governor's Office of Planning & Resear			rch	Poter Connelly	9/8/2020 Sr, Environmental Planning Section
Sep 08 2020				Office of Facility	Planning, Construction, and Management ment of Corrections and Rehabilitation

STATE CLEARING HOUSE