NOTICE OF EXEMPTION		
To: ⊠ Office of Planning and Research 1400 Tenth Street, Room 121	From: ABC Unified School District	
Sacramento, CA 95814	16700 Norwalk Blvd	
	Cerritos, CA 90703	
County Clerk     County of Los Angeles		
12400 Imperial Highway		
Norwalk, CA 90650		
Solar Energy Project - Kennedy Stem Acade	emv	

The District proposes to install solar energy array on elevated carport structure (Structure A) at Kennedy Academy. Structure A would be installed over the multipurpose field behind the portable classroom buildings and comprised of metal columns and beams supporting array panels. Structure A would be a minimum of 10-foot high and consists of 228 photo-voltaic (PV) modules tilted at a 7-degree angle. The solar system would have the direct current (DC) system size of 95.760 kilowatts (kW). Approximately 554 feet of conduit would be installed by directional borings from the solar array through paved lots and grass area to an existing electrical equipment box between the school buildings. The project would also provide underground conduit for installation of car chargers in the future. However, Installation of car chargers require additional funding and would not be installed at this time. The District and general community will benefit from a reduction in energy consumption and reduced energy costs.

Los Angeles

Project Location - County

Description of Nature, Purpose, and Beneficiaries of Project

ABC	Unified	School	District

**Project Title** 

Artesia

17500 Belshire Avenue Project Location - Specific

Project Location - City

Name of Public Agency Approving Project

## **ABC Unified School District**

Name of Person or Agency Carrying Out Project

CEQA: California Environmental Quality Act \_\_

CEQA: California Environmental Quality Act	
Exempt Status: (check one below)	
☐ Ministerial (Sec. 21080(b)(1); 15268);	
☐ Declared Emergency (Sec. 21080(b)(3); 15269	(a));
☐ Emergency Project (Sec. 21080(b)(4); 15269(b	)(c));
	number: §15301 Class 1, Existing Facilities, §15303 Class ructures, §15314 Class 14, Minor Addition to Schools
☐ Statutory Exemptions. State code number:	
solar array will not result in an increase in stude improvements will occur. Existing use of the fac proposed project. Therefore, the proposed project 15314. The proposed project was also reviewed for the exceptions do not apply.	f solar energy array on an elevated structure. The proposed nt capacity or an expansion of existing use. No off-campus ility as an elementary school will stay the same under the it is exempt from CEQA under Sections 15301, 15303, and or possible exceptions under Section 15300.2 and found that explanation of the evaluation, which is available at the ABC, Cerritos, CA 90703.
Ryan Carter	(562) 926-5566
Contact Person:	Area Code/Telephone/Extension:
If filed by applicant:  1. Attach certified document of exemption filed by the project  Date Received for Filing:  Signature:	