State of California Department of Parks and Recreation

NOTICE OF EXEMPTION

TO: Office of Planning and Research

FROM:

Department of Parks and Recreation

1400 Tenth Street

750 Hearst Castle Rd

Sacramento, CA 95814

San Simeon, CA 93452

PROJECT TITLE: Hearst Castle Mainline Repair

LOCATION: Hearst San Simeon State Historical Monument

COUNTY: San Luis Obispo

DESCRIPTION OF THE NATURE AND PURPOSE OF PROJECT:

Repair a leaking water mainline at Hearst San Simeon State Historical Monument to ensure a continued water supply to Hearst Castle. Work will:

- Reroute a 350-foot section of suspended mainline to a new location along the access road.
- Clear vegetation, including trees less than 8 inches diameter, along the mainline for access.
- Regrade approximately 2,000 feet of existing ranch road to improve access to the site.
- Install a new 350-foot section of 6-inch diameter schedule 80 pipe.
- Use flanges to connect the new 6-inch diameter pipe to the existing 5-inch steel pipe.

PUBLIC AGENCY APPROVING THE PROJECT: California Department of Parks & Recreation

NAME OF DIVISION OR DISTRICT CARRYING OUT THE PROJECT: San Luis Obispo Coast

EXEMPT STATUS

 Classes: 1, 4

Sections: 15301, 15304

REASONS WHY PROJECT IS EXEMPT:

This project consists of the operation, repair, maintenance, or minor alteration of existing public or private structures, facilities, mechanical equipment, or topographical features, involving negligible or no expansion of use beyond current levels and is included as "Utility repairs or minor upgrades" in the Department of Parks and Recreation's list of exempt activities in accordance with CCR §15300.4, and minor public or private alterations in the condition of land, water, and/or vegetation which do not involve removal of healthy, mature, scenic trees.

CONTACT: Doug Barker, District Environmental Coordinator TELEPHONE: (805)927-2119

San Luis Obispo Coast District EMAIL: Doug.Barker@parks.ca.gov

Dan Falat, District Superintendent

DATE 7/12/22